

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED

STATE OF OREGON

(Please type or print)

OCT 15 1975

(Do not write above this line)

State Well No. ~~7-13-76~~

State Permit No. 8s 2w-6

9622
M 121.000
G-12317

WATER RESOURCES DEPT.

(1) OWNER: SALEM, OREGON

Name City of Salem
Address 555 Liberty S. E.
Salem, Oregon 97301

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 110 ft. Gage 330
" Diam. from ft. to ft. Gage 322
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Baller test 100 gal./min. with 30 ft. drawdown after 2 hrs.
Artesian flow g.p.m.

Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION: cement
Well seal—Material used 110
Well sealed from land surface to ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in. 33
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number ~~XXXXX~~ 1701075D
NE $\frac{1}{4}$ SW $\frac{1}{4}$ Section 46 T. 8S R. 2W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 15 ft.
Static level 11 ft. below land surface. Date 10-3-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 110 ft. Depth of completed well 110 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
gravel & silt	0	2	
gravel & sand boulders	2	18	11'
glowing sand & gravel	18	26	
gravel & heavy sand	26	32	
black gravel & clay	32	35	
gray gravel & sand & clay	35	41	
brown sand & gravel & clay	41	49	
gravel & sand	49	54	
brown conglomerant -dry	54	57	
gravel/sand	57	63	
gravel & sand with clay	63	78	
clay & sand - a little gravel	78	80	
sand, clay & gravel-decomposed	80	101	
brown sand & gravel & clay	101	108	
gravel & sand	108	110	

Work started 9-17 19 75 Completed 10-3 19 75
Date well drilling machine moved off of well 10-3 19 75

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] J. Schwen Date 10/14, 19 75
(Drilling Machine Operator)
Drilling Machine Operator's License No. 594

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schoen Electric & Pump (Type or print)
Address 626 W. Queen Avenue - Albany, Or. 97321
[Signed] Jerry E. Schoen
(Water Well Contractor)
Contractor's License No. 513 Date 10/14 19 75