

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED AUG 29 1968

STATE OF OREGON WATER WELL REPORT

9624 MA 11111

State Well No. 8/2w-6 E dab

STATE ENGINEER, SALEM (Please type or print) SALEM OREGON (Do not write above this line)

State Permit No.

20 Meadowlark Mobile Homes

(1) OWNER:

Name ERNEST L. JONES Address 1842 LANCASTER S E, SALEM, ORE

(11) LOCATION OF WELL:

County Marion Driller's well number SW 1/4 NE 1/4 Section 6 T. 8 S R. 2 W W.M.

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

Bearing and distance from section or subdivision corner 2600' S and 1500' W NE Cor. Sec 6 Meadowlark Mobile Manor 2870 Lancaster Dr. SE Salem, Ore

(12) WELL LOG: Diameter of well below casing 8" Depth drilled 122 ft. Depth of completed well 122 ft.

CASING INSTALLED:

8" Threaded [ ] Welded [X] 8" Diam. from plus L ft. to 117 ft. Gage 250

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Clay-tan, Gravel & sand-tightly cemented, small flows of water throughout, etc.

PERFORATIONS:

Perforated? [X] Yes [ ] No. Type of perforator used torch perforations Size of perforations 3/16 in. by 12 in. 20 perforations from 113 ft. to 117 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 21 ft. below land surface Date 8/16/68 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? Driller Yield: 130 gal./min. with 74 ft. drawdown after 2 hrs. 140 " 84 " 1 " 150 " 94 " 1 "

Work started 6 Aug 68 19 Completed 15 Aug 68 19 Date well drilling machine moved off of well 16 Aug 68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Howard Duffield Date 17 Aug., 1968. (Drilling Machine Operator)

Drilling Machine Operator's License No. 46

(10) CONSTRUCTION:

Well seal—Material used bentonite & drillings Depth of seal 22' plus ft. Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME DUFFIELD BROS. (Person, firm or corporation) (Type or print)

Address 4123 BLUFF AVE S E, SALEM, ORE.

[Signed] Howard Duffield (Water Well Contractor)

Contractor's License No. 15 Date 17 Aug., 1968.