

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

# RECEIVED WATER WELL REPORT

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON  
OCT 9 1978 (Please type or print)

State Well No. 85/2w-10  
State Permit No. 9756

WATER RESOURCES DEPT.  
SALEM, OREGON

### (1) OWNER:

Name Joseph Johnson  
Address 8753 Ranay Dr. SE  
Salem Oregon

### (2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

### (3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

### (4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

### CASING INSTALLED:

Threaded  Welded

6" Diam. from 71 ft. to 70 ft. Gage 250  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

### PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used Torch

Size of perforations 3/8 in. by 6 in.  
15 perforations from 57 ft. to 70 ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.

### (7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name .....

Type ..... Model No. ....

Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

### (8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" All " " "

Artesian test 25 gal./min. with 118 ft. drawdown after 1/2 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ..... ft.

### (9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 49 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 16 sacks

How was cement grout placed? Air Grout Pump

.....

.....

Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.

Did any strata contain unusable water?  Yes  No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed?  Yes  No Size of gravel: 3/4

Gravel placed from 49 ft. to 70 ft.

### (10) LOCATION OF WELL:

County Marion Driller's well number  
1/4 Section 10 T. 85 R. 2w W.M.  
Bearing and distance from section or subdivision corner

### (11) WATER LEVEL: Completed well.

Depth at which water was first found 47 ft.

Static level 22 ft. below land surface. Date 9-12-78

Artesian pressure lbs. per square inch. Date

### (12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Dark Brown Clay	1	6	
Brown Clay with Decomposed Rock	6	27	
Large Cobbles	27	35	
Thin Clay	35	38	
White Clay Sticky	38	42	
Brown Clay with Decomposed Rock	42	45	
Decomposed Rock	45	65	
Black Basalt	65	72	
Weathered Basalt	72	76	
Gray Basalt	76	82	
Weathered Basalt	82	87	
Gray Basalt	87	123	
Blue Green Sandy clay	123	140	22'

Work started 9-9 1978 Completed 9-12 1978

Date well drilling machine moved off of well 9-12 1978

### Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J.D. Mander Date Sept. 13, 1978  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1195

### Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name MILLER & WEST DRILLING  
(Person, firm or corporation) (Type or print)

Address 5875 GAFIN Rd. S.E.

[Signed] Michael Waldrop  
(Water Well Contractor)

Contractor's License No. 633 Date Sept. 13, 1978