

MA 31...
9792
PLEASE

RECEIVED 8S/2W/11 BA

JUL 21 1988

WATER RESOURCES DEPT (for official use only)

(10) LOCATION OF WELL by legal description:

County Marion NE $\frac{1}{4}$ NW $\frac{1}{4}$ of Section 11 of Township T8S, Range 2W, WM. (Township is North or South) (Range is East or West)
Tax Lot 75340-110 Lot _____ Block _____ Subdivision _____

MAILING ADDRESS OF WELL (or nearest address) 7745 Harpole St.
Salem, Ore. 97301

(11) WATER LEVEL of COMPLETED WELL:

(4) PROPOSED USE (check):

Depth at which water was first found	42	ft.
Static level	15	ft. below land surface. Date 7/18/88
Artesian pressure		lbs. per square inch. Date

Steel ☒ Plastic ☐

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 85' ft. Depth of completed well 85' ft.

Steel ☐ Plastic ☐
Threaded ☐ Welded ☐

" Diam. from ft. to ft. Gauge

Perforated? ☒ Yes ☐ No

Size of perforations	<u>3/8</u>	in. by	<u>4</u>	in.
	<u>10</u>	perforations from	<u>81</u>	ft. to <u>79</u> ft.
		perforations from		ft. to
		perforations from		ft. to

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot Size Set from ft. to ft

Diam. Slot Size Set from ft. to ft

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?				
Yield:	gal./min. with	ft. drawdown after	hrs	
"	"	"	"	
Air test	40 gal./min. with drill stem at	80 ft.	1	hrs
Water test	gal./min. with	ft. drawdown after	hrs	
Artesian flow	g.p.m.			
Temperature of water	Depth artesian flow encountered ft			

Special standards: Yes ☐ No ☒

Well seal—Material used Cement
Well sealed from land surface to ($\frac{1}{4}$ —crushed packer 40—37' ft
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 10 in.
Amount of sealing material 21 $\frac{1}{2}$ sacks ☒ pounds ☐
How was cement grout placed? 1 $\frac{1}{2}$ " tremie pipe & air diaph-
ram pump.

Was pump installed? no Type HP Depth ft
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata

Method of sealing strata off _____

Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/4" rd

Gravel placed from 81 ft. to 40 ft.

(12) WELL LOG:

Depth drilled 85' ft. Depth of completed well 85' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

[illegible]

Date work started 7/14/88 /completed 7/18/88
Date well drilling machine moved off of well 7/18/88 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. J. V. Lemaire Date 7/20/88 19 88

(bonded) Water Well Constructor Certification:

Bond 2035392 Issued by: Western Surety Co.
(number) (Surety Company Name)
On behalf of Peter J. Tolmasoff
(type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

A O M

(Signed) John J. O'Connell
(Water Well Constructor)

(Dated) 7/20/88 V W

NOTICE TO WATER WELL CONSTRUCTOR

The original and first copy of this report

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310

SP*46866-690