## WATER WELL REPORT STATE OF OREGON

RECEIVED OCT 281983 WATER RESOURCES DEPT.

\$	85/2W-116d
State Well No	00 11 00 C
A Part of the second	1
State Permit No.	

(1) OWNER:	(10) LOCATION OF WELL:
Name Cak Lane Farms	County Marion Driller's well number Rieck Farm
Address 3167 Oak Lane NE	SE 14 NW 14 Section 11 T. SS R. 2W W.M.
City Mt. Angel State Or.	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: 7882 Jordan Rd. SE
	Salem, Or.
New Well □ Deepening □ Reconditioning □ Abandon □ □  If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 339 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 16 ft. below land surface. Date 10-17-8
Rotary Air Driven Domestic Industrial Municipal Description To Test Well Dother	Artesian pressure lbs. per square inch. Date
Rotary Mud	(12) WELLLOG: Diameter of well below casing 8" -250-500'
CACING INCHALLED.	Depth drilled 500 ft. Depth of completed well 500 ft.
(5) CASING INSTALLED: Steel  Plastic  Welded  Welded	Formation: Describe color, texture, grain size and structure of materials; and show
	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
"Diam. from	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	Basalt hard, fract-blk 250 277
	Glaystn med green 277 316
(6) PERFORATIONS: Perforated? ☐ Yes ☐ No	Sandstn hard green 316 445 H20
Type of perforator used Size of perforations in. by in.	Sandstn 1t green 445 490 H20
perforations from	Sandstn hard green 490 500
perforations from	
perforations from	
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	
Manufacturer's Name	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot SizeSet fromft. toft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes Ⅺ No If yes, by whom?	
d: gal/min. with ft. drawdown after hrs.	
"	
Air test 700 gal/min. with drill stem at 500 ft. 2 hrs.	
Bailer test gal/min. with ft. drawdown after hrs.	
Artesian flow g.p.m.  Depth artesian flow encountered	10.11 00 10.17 92
Appendix of Mater	Work started         10-14         1983         Completed         10-17         1983           Date well drilling machine moved off of well         10-18         1983
(9) CONSTRUCTION: Special standards: Yes \(\Delta\) No \(\Delta\)	Date No. 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
Well seal—Material used	(unbonded) Water Well Constructor Certification (if applicable):
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore to bottom of sealin.	[Signed] Date, 19
Diameter of well bore below seal	Bonded Water Well Constructor Certification:
How was cement grout placed?	Bond Issued by: Union Indemnity
riow was cement grout placed:	(number) Surety Company Name
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was pump installed? NO Type HP Depth ft.	Name West Coast Drilling Co. Inc.
Was a drive shoe used?	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water?   Yes  No	Address 220 Academy St. Angel, Or.
Type of Water? depth of strata	[Signed] huch ythin
Method of sealing strata off	Water Well Constructor  Date
Was well gravel packed? Yes No Size of gravel:	Date, 19.63.
Gravel placed fromft. toft.	