NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED MAR 12 1979 WATER RESOURCES DEPT. SALEM, OREGON

# WATER WELL REPORT
## STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED MAR 26 1979 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 5N/26E-25 dc
State Permit No. MORR 1169

**(1) OWNER:**
Name Max Heilberg
Address Rt 2 Box 452
Irrigon, Oregon 97844

**(2) TYPE OF WORK (check):**
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

**(4) PROPOSED USE (check):**
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

**CASING INSTALLED:** Threaded ☐ Welded ☒
10" Diam. from +1 ft. to 49 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

**PERFORATIONS:** Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

**(7) SCREENS:** Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
~~Bailer test~~ AIR 300 gal./min. with 29 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**
Well seal—Material used Cement
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 19 sacks
How was cement grout placed? Cement was placed from bottom to top of oversized drill hole as temporary casing was withdrawn.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**
County Morrow Driller's well number
SW ¼ SE ¼ Section 25 T. 5N. R. 26E. W.M.
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**
Depth at which water was first found 39 ft.
Static level 31 ft. below land surface. Date 2-16-79
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:** Diameter of well below casing 10"
Depth drilled 50 ft. Depth of completed well 50 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| Topsoil | 0 | 4 | |
| Sand, gray | 4 | 30 | |
| Gravel | 30 | 39 | |
| Gravel & sand | 39 | 50 | W.B. |

Work started 2-15 1979 Completed 2-16 1979
Date well drilling machine moved off of well 2-16 1979

**Drilling Machine Operator's Certification:**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] James T. Leith (Drilling Machine Operator) Date 2-19, 1979
Drilling Machine Operator's License No. 665

**Water Well Contractor's Certification:**
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name TROY GRIFFIN (Person, firm or corporation) (Type or print)
Address 900 HERMISTON AVE. HERMISTON ORE
[Signed] Troy Griffin (Water Well Contractor)
Contractor's License No. 65 Date 2-19, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119