

The original and first copy of this report are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED

STATE OF OREGON (Please type or print)

MORR 1232

State Well No. 5W/26E 26cc

State Permit No.

APR 9 1979

(Do not write above this line)

WATER RESOURCES DEPT.

(1) OWNER: SALEM, OREGON

Name: Robert V. Gillett
Address: Rt 2 Box 184
Perigon Oregon 97844

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]

(10) LOCATION OF WELL:

County: Morrow Driller's well number:
SW 1/4 SW 1/4 Section 26 T. 57N. R. 26E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 75 ft.
Static level 58 ft. below land surface. Date 3-28-79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 103 ft. Depth of completed well 105 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Entries include Topsoil, Gravel, Sand & gravel, Gravel with water-bearing strata (W.B.).

(6) CASING INSTALLED:

12" Diam. from 1 ft. to 103 ft. Gage 250
Threaded [ ] Welded [X]

(7) PERFORATIONS:

Perforated? [ ] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No. If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
AIR test 800 gal./min. with 42 ft. drawdown after 1 hrs.

(9) CONSTRUCTION:

Well seal—Material used: Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 12 sacks
How was cement grout placed? Cement placed by tremie pipe from bottom to top of oversized blank hole as temporary casing was wash drawn
Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

Work started 3-26 1979 Completed 3-28 1979
Date well drilling machine moved off of well 3-28 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] James T. Leitch Date 3-28, 1979
(Drilling Machine Operator)
Drilling Machine Operator's License No. 665

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name: TROY GRIFFIN (Person, firm or corporation)
Address: 900 HERMISTON AVE, HERMISTON ORE
[Signed] Troy Griffin (Water Well Contractor)
Contractor's License No. 65 Date 3-28, 1979