NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAR 18 1974 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED DEC 4 1974 STATE ENGINEER SALEM, OREGON

ab

State Well No. 5N/26E-27

State Permit No. MORR 1248

(1) OWNER:
Name Don Kenney
Address Irrigon Ore

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
2" Diam. from 0 ft. to 140 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Mills Knife
Size of perforations ½ in. by 2 in.
102 perforations from 62 ft. to 90 ft.
697 perforations from 112 ft. to 135 ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom? J. R. Fredrickson
Yield: gal./min. with 14 ft. drawdown after 1 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water 300 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 1½"
Gravel placed from 24 ft. to dont know

(10) LOCATION OF WELL:
County Morrow Driller's well number
NW ¼ NE ¼ Section 27 T. 5N R. 26 W.M.
Bearing and distance from section or subdivision corner 700 East & 25 South of NW corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 31 ft.
Static level 28 ft. below land surface. Date Aug 10
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled ft. Depth of completed well ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Topsoil	0	6	
Cement Gravel	6	24	
Gravel & Sand	24	36	28
Sand	36	46	28
Coarse Sand	46	50	28
Sand & Gravel	50	70	28
Sand	70	71	24
Sand & Gravel	71	91	24
Sand	91	100	26
Sand & Gravel	100	108	25
Gravel & Some	108	135	
Cement Sand	108	135	
Gravel & Clay	135	140	

Work started Aug 10 1973 Completed Nov 16 1973
Date well drilling machine moved off of well May 17 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] J. R. Fredrickson (Drilling Machine Operator) Date Feb 6, 1974
Drilling Machine Operator's License No. 357

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name JOHN R. EDWARDS (Person, firm or corporation) (Type or print)
Address LEXINGTON ORE
[Signed] John R. Edwards (Water Well Contractor)
Contractor's License No. 479 Date 3-12, 1974

50 X dia 100 X 5 2 1 4 8 0 7

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119