NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL EFFORD E IVE STATE OF OREGON NOV 19 1971 State Well No. 5N/24E-33 CAC

(Please type or STATE ENGINEE Permit No. (Do not write above this line) EM OREGON

MO	P	171/
	ンソ	

(1) OWNER:	(10) LOCATION OF WELL:		
Name DESERT MAGIC, INC.	County Morrow Driller's well number		
Address P.O.Box 216	NE 14 NE 14 Section 33 T. 5NO . R. 26E W.M.		
Boardman, Oregon (2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner		
	1320'South & 1320' West of NE Corner Sec 33		
New Well Deepening Reconditioning Abandon			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Donth of which water		
Rotary Driven Domestic Industrial Municipal Domestic	710		
Dug ☐ Bored ☐ Irrigation ☒ Test Well ☐ Other ☐	1. 10. below land surface. Date / - 11-/1		
	Artesian pressure lbs. per square inch. Date		
CASING INSTALLED: Threaded □ Welded ₩	(12) WELL LOG: Diameter of well below seeing		
16. "Diam. from 0 ft. to 124 ft. Gage 250	Diameter of well below casing		
"Diam. fromft. toft. Gage	124 P 12 completed wen 124 H.		
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,		
PERFORATIONS: Perforated? W Yes No.	with at least one entry for each change of formation. Report each change in		
Type of perforator used Manhains	position of Static Water Level and indicate principal water-bearing strata.		
- /n /	MATERIAL From To SWL		
Size of perforations 3/16 in. by 3 in. perforations from 96 ft. to 124 ft.	top soil 0 1		
perforations fromft. toft. toft.	coarse gray sand 1 16		
perforations fromft. toft.	hard gray clay 16 18		
	coarse black sand 18 29		
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	coarse sand & gravel 29 51		
Manufacturer's Name	gravel & boulders 51 112		
TypeModel No.	sand & gravel 112 114		
Diam. Slot size Set from ft. to ft.	fine sand 122 124		
Diam, Slot size Set from ft. to ft.	11ne sand 122 124		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? X Yes \(\simega \) No. If yes, by whom? \(\sum_{\text{filler}} \)			
Yield: 1336 gal./min. with 25 ft. drawdown after 12 hrs.			
" " " " " " " " " " " " " " " " " " "			
Bailer test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m.			
Temperature of water Depth artesian flow encountered ft.	Work started 7-7 1977 Completed ### 7.77 10.77		
(9) CONSTRUCTION:	2 - 1 19 /1		
	Date well drilling machine moved off of well 7-10 19 71		
Well seal—Material used	Drilling Machine Operator's Certification:		
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used and information reported above are true to my		
Diameter of well bore to bottom of seal 24 in.	best knowledge and belief.		
Diameter of well bore below seal 24 in.	[Signed] Moote Date Of 19, 197/		
Number of sacks of cement used in well sealsacks Number of sacks of bentonite used in well sealsacks			
Brand name of bentonitesacks	Drilling Machine Operator's License No		
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this		
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.			
Did any strata contain unusable water? ☐ Yes [¥No	Name Desert Magic, Inc. (Person, firm or corporation) (Type or print)		
Type of water? depth of strata	(Type or print)		
35-47-3	Address Box 216/ Boardman, Onegon 97818		
was well gravel packed? ✓ Yes No Size of gravel: 1/8 to 3/8	[Signed] Hward Kartener		
Gravel placed from	(Water Well Contractor)		
(USE ADDITIONAL CONT.	Contractor's License No Date Oct. 19, 1977		