NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Do not write above this line) LEM ORGETS653

1) OWNER:	(10) LOCATION OF WELL:
Name DESERT MAGIC, INC. #3	County Morrow Driller's well number
Address P.O.Box 216	NW 14 NE 14 Section 34 T. 5 No R. 26 E W.M.
Boardman, Oregon	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	1395' West of NE corner sec 34
New Well Deepening Reconditioning Abandon	50 South
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 62 ft.
Rotary 🔯 Driven 🗆 Domestic 🗎 Industrial 🗎 Municipal 🗀	Static level 62 .ft. below land surface. Date 6-25-71
Cable	Artesian pressure lbs. per square inch. Date
Dug ☐ Bored ☐ Irrigation & Test Well ☐ Other ☐	Artesian pressure ibs. per square incir. Date
CASING INSTALLED: Threaded □ Welded 🖼	(12) WELL LOG: Diameter of well below casing
16	Depth drilled ## 110ft. Depth of completed well 110 ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials;
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? M Yes C No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
	MATERIAL From To SWL
Type of perforator used Machine	
Size of perforations 3/16 in. by 3 in.	top soil 0 3 coarse sand 3 35
perforations from 90 ft. to 110 ft.	coarse sand 3 35 sand & gravel 35 75
perforations fromft. toft.	gravel & boulders 75 110
perforations fromft. toft.	STAVET & DOUTHOLD
(7) SCREENS: Well screen installed? Yes No	
Manufacturer's Name	E
Type Model No	
Diam Slot size Set from ft. to ft.	
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? XYes \(\subseteq \) No If yes, by whom? \(\subseteq \) It is a pump test made?	
	I seemed at the
Yield: 1350 gal./min. with 26 ft. drawdown after 12 hrs.	
" " "	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
Temperature of water Depth artesian flow encountered ft.	Work started 6-17 19 71 Completed 6-27 1571
(9) CONSTRUCTION:	Date well drilling machine moved off of well 6-25 19 71
Well seal-Material usedCement	Drilling Machine Operator's Certification:
Well sealed from land surface to62ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal24 in.	best knowledge and belief.
Diameter of well bore below seal24 in.	[Signed] Moore Date at 19, 1971.
Number of sacks of cement used in well seal110 sacks	Drilling Machine Operator's License No
Number of sacks of bentonite used in well seal sacks	Diffing Machine Operators Precise 110
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of water	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes No	Name Desert Magic, Inc. (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Box 216 Boardman, Oregon 97818
Method of sealing strata off Was well gravel packed? ★ Yes No Size of gravel: 1/8 to 3/8	[Signed] Howard Last merhenden (Water Well Contractor)
(2) 130	Contractor's License No Date Oct
Gravel placed from QC ft. to ft.	COLLEGE DE LACCELOCE LEGS LOUIS LOUIS CONTRACTOR