

WATER WELL REPORT

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 25/26E-2366

State Permit No. _____

(Do not write above this line)

WATER RESOURCES
DEPARTMENT, OREGON

W.R. file indicates 23 cac; MSJ

(1) OWNER:

Name Dail Turner & Robert Shultz
Address Rt 2 Box 2064
Heppner, Oregon 97836

(2) TYPE OF WORK (check):

New Well ☐ Deepening ☒ Reconditioning ☒ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒
Cable ☐
Dug ☐

Driven ☐
Jetted ☐
Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

10" Diam. from 0 ft. to 38 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used _____

Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
an 200 gal./min. with 365 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.

Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 13 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 16 sacks
How was cement grout placed? _____

Was a drive shoe used? ☒ Yes ☐ No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Morrow Driller's well number _____
N.W. 1/4 SW 1/4 Section 23 T. 28. R. 26 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found _____ ft.

Static level 85 ft. below land surface. Date 5-16-78

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8" 450' to 674'

Depth drilled 246 ft. Depth of completed well 674 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Basalt, gray	428	507	
Rock, black & blue claystone	507	534	
Basalt, gray	534	572	
Rock, red	572	584	W.B.
Basalt	584	617	
Rock, hard, gray	617	635	
Rock, brown & green claystone	635	664	W.B.
Rock, black	664	674	

Reamed & drilled
10" hole to 450'
8" hole from 450' to 674'

Work started 5-3 19 78 Completed 5-10 19 78

Date well drilling machine moved off of well 5-10 19 78

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] James T. Litch Date 5-10, 19 78
(Drilling Machine Operator)

Drilling Machine Operator's License No. 665

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name TRAY GRIFFIN
(Person, firm or corporation) (Type or print)

Address 900 HERMISTON AVE, HERMISTON OR

[Signed] Tray Griffin
(Water Well Contractor)

Contractor's License No. 65 Date 5-10, 19 78