NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON ~~97310~~ within 30 days from the date of well completion.

MORR 206

Heppner, Oreg (From Cmd)

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
NOV 27 1973
STATE ENGINEER
SALEM, OREGON

BLB ~~EB~~

State Well No. 2S/28E-29

State Permit No. G6837

(1) OWNER:
Name ~~Tech Baker~~ DON GREENUP
Address

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
8" Diam. from 0 ft. to 23 ft. Gage .277
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
AIR Bailer test 400 gal./min. with 12 ft. drawdown after 1 hrs.
Artesian flow g.p.m. –
Temperature of water 60° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 12 sacks
Number of sacks of bentonite used in well seal 0 sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Morrow Driller's well number 46
NW ¼ SW ¼ Section 29 T. 2S R. 28E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 69 ft.
Static level 12 ft. below land surface. Date 10-11-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8
Depth drilled 197' ft. Depth of completed well 197 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
SOIL	0	5	
GRAVEL	5	17	
BLACK BASALT	17	69	
BLACK BASALT W/GREEN	69	160	
SOAP STONE + IRON			
PYRITE ALL WATER			
BEARING			12'
BLACK BASALT	160	197	
	82	95	86
	95	100	156
	100	101	246
	100	102	306
	102	111	406
WATER	111	114	606
	114	126	606
	126	135	1006
	135	160	400G

Work started 10-9 1973 Completed 10-12 1973
Date well drilling machine moved off of well 10-12 1973

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Jan Gillespie (Drilling Machine Operator) Date 10-12, 1973.
Drilling Machine Operator's License No. 836

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name LARRY BIRD WELL DRILLING (Person, firm or corporation) (Type or print)
Address PO BOX 417 Pendleton Ore
[Signed] Larry Bird (Water Well Contractor)
Contractor's License No. 544 Date 10-12, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119