

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

MORR 223

WATER WELL REPORT

STATE OF OREGON

(Please type or print) 2 1968
(not write above this line)

STATE ENGINEER

State Well No. 3/24-23

State Permit No.

STATE ENGINEER, SALEM, OREGON 97301

within 30 days from the date of well completion.

(1) OWNER:

Name LEONARD R. HILLAddress HOPPER, OREGON

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☒ Other ☐

CASING INSTALLED:

8/8" Diam. from C ft. to 20 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used _____

Size of perforations	in.	by	in.
_____ perforations from _____ ft. to _____ ft.			
_____ perforations from _____ ft. to _____ ft.			
_____ perforations from _____ ft. to _____ ft.			
_____ perforations from _____ ft. to _____ ft.			
_____ perforations from _____ ft. to _____ ft.			

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 38' ft. below land surface Date Oct 24

Static pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" FOR LIFT " 100 GPM " _____

" " " " " _____

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 57 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used BENTONITEDepth of seal 20 ft.Diameter of well bore to bottom of seal 12" in.Were any loose strata cemented off? ☐ Yes ☒ No Depth _____Was a drive shoe used? ☐ Yes ☒ NoDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County MORROW Driller's well number _____1/4 1/4 Section 23 T. 33 R. 24E W.M.

Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 8"-6 3/4"-6"Depth drilled 355 ft. Depth of completed well 355 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	6	
Gravel	6	9	
Basalt-Black	9	123	
Basalt Red	123	142	
Broken Basalt & clay	142	157	
Basalt Broken water	157	164	
Basalt Black	164	197	
Basalt soapstone	197	199	
Basalt Black	199	327	38'
Basalt Red water	327	346	35'
Basalt Black	346	355	38'

Work started Oct 16 1968 Completed Oct 24 - 1968Date well drilling machine moved off of well Oct 25 - 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] M. W. Robertson Date Oct 25, 1968
(Drilling Machine Operator)Drilling Machine Operator's License No. 577

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Otto Ellsworth
(Person, firm or corporation) (Type or print)Address P.O. Box 471 Island City[Signed] Otto Ellsworth
(Water Well Contractor)Contractor's License No. 398 Date 10/24, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)