

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

MORR 239

WATER WELL REPORT

STATE OF OREGON OCT 23 1968

(Please type or print)
(Do not write above this line)

STATE ENGINEER
SALEM, OREGON

3/25-34 D

(1) OWNER:

Name Harold Wright #2
Address Ruggs Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☐
" Diam. from 0 ft. to 19 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used _____

Size of perforations	in.	by	in.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 22' ft. below land surface Date Sept 25
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom? _____

_____ gal./min. with _____ ft. drawdown after _____ hrs.
AR Lift 240 GPM

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____

Temperature of water 57 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 20' ft.
Diameter of well bore to bottom of seal 13 3/4 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth _____
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Morrow Driller's well number 2
1/4 1/4 Section 24 T. 3 R. 25E W.M.

Bearing and distance from section or subdivision corner _____

(12) WELL LOG;

Diameter of well below casing 10"

Depth drilled 250 ft. Depth of completed well 250 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	3	
Gravel	3	6	
Basalt - Black	6	50	
Basalt - Red - Brown	50	110	
Red Basalt water	110	114	
Basalt Black	114	230	
Basalt w/ clay water	230	240	
Basalt Black hard	240	250	

Work started Sept 21 1968 Completed 10-1- 1968

Date well drilling machine moved off of well 10-1-68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Mr. Robertson Date 10-3- 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 577

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Otto Ellsworth
(Person, firm or corporation) (Type or print)

Address (471 P.O. Box) Island City, Oregon

[Signed] Otto Ellsworth
(Water Well Contractor)

Contractor's License No. 398 Date 10/18 1968

(USE ADDITIONAL SHEETS IF NECESSARY)