

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filled with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

MORR 243

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED
OCT 23 1968
STATE ENGINEER
SALEM, OREGON

State Well No. 3/25-35 N

Permit No.

(1) OWNER:

Name Harold Wright
Address Ruggs Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☐

1" Diam. from 0 ft. to 19 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 34' ft. below land surface Date 10-4-
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Well: _____ gal./min. with _____ ft. drawdown after _____ hrs.
AIR 1.5 ft 250 GPM " " " "

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 58 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 19' ft.
Diameter of well bore to bottom of seal 13 3/4 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth _____
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County MORROW Driller's well number 3
1/4 1/4 Section 35 T. 3 S. R. 25E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10 1/2 "

Depth drilled 320' ft. Depth of completed well 320 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	9	
Gravel	9	12	
Basalt Black Hard	12	50	
Basalt Red w/ clay	50	60	
Basalt - Black	60	183	
Basalt Red water	183	190	
Basalt Black	190	282	
Basalt-Red w/ clay	282	300	
Basalt Black hard	300	320	

Work started 10-1- 1968 Completed 10-16- 1968

Date well drilling machine moved off of well 10-16- 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] M. W. Robertson Date 10-17- 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 577

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Otto Ellsworth
(Person, firm or corporation) (Type or print)

Address P.O. Box 471 Island City Oregon

[Signed] Otto Ellsworth
(Water Well Contractor)

Contractor's License No. 398 Date 10/18, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)