

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

MORR 27

State Well No. 15/24E-12cd
State Permit No. _____

(Do not write above this line)

(1) OWNER:

Name JERRY McELLIOTT
Address HEPPNER LEXINGTON HY
10NE ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
C Jetted
D Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
12" Diam. from +1 ft. to -1.9 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No.

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

AIR
a pump test made? Yes No If yes, by whom? DRILLER
Yield: 1000+ gal./min. with 180 ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
Pump test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 58^o Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? TRENCH
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County MORROW Driller's well number _____
SE 1/4 SW 1/4 Section 12 T. 15 R. 24E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 130 ft.
Static level 6 ft. below land surface. Date 8-27-80
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 475 ft. Depth of completed well 475 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SAND	0	4	
SAND & GRAVEL	4	12	
BASALT Black	12	130	
" Grey / 50	130	140	
" Black	140	148	
" DRIVEN - H ₂ O	148	160	
" Black	160	185	
" Grey	185	190	
" Grey - BR - H ₂ O	190	260	700 G
" Black	260	469	
" Black	469	475	1000 + G

RECEIVED

DEC 31 1980

WATER RESOURCES DEPT
SALEM, OREGON

Work started 8-18 1980 Completed 8-27 1980
Date well drilling machine moved off of well 8-28 1980

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Mike Mullin Date Aug 28, 1980
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1386

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Larry Burd Well Drilling Inc
(Person, firm or corporation) (Type or print)

Address Pendleton Ore

[Signed] Larry Burd
(Water Well Contractor)

Contractor's License No. 5441 Date 8-28, 1980