

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

ROTARY AIR DRILLED

MORR385

WATER WELL REPORT

STATE OF OREGON APR 7 1969

State Well No.

1N/23-34 adc

(Please type or print)

(Do not write above this line)

State Permit No.

STATE ENGINEER
SALEM OREGON

SAG-4794

(1) OWNER:

Name MARY LINDSAY
Address FONE, OREG.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

10" Diam. from 0 ft. to 19 ft. Gage 222
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level ft. below land surface Date 4/2/68
Artesian pressure 8 lbs. per square inch Date 11/30/68

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

gal./min. with ft. drawdown after hrs.
" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 19 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☒ Yes ☐ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MORROW Driller's well number 85
SE 1/4 NE 1/4 Section 34 T. 1N R. 23E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 122 ft. Depth of completed well 122 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil SANDY	0'	4'	
GRAVEL & Boulders	4'	9'	
Rock BASALT GRAY	9'	19'	
BASALT-GRAY	19'	86'	
LAVA Rock Red & BIK.	86'	118'	
Rock-BASALT-GRAY	118'	122'	
Approx. 45 gal. water per min. Artesian 10" gate valve & coupler installed on top of coupling			

Work started 11/25 1968 Completed 11/30 1968
Date well drilling machine moved off of well 11/30 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Frank A. Crowe Date Jan 6, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 280

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME EDMUND BOEHRS WELL DRILLING
(Person, firm or corporation) (Type or print)

Address Box 414 OAKLAND ORE

[Signed] Edmund Boehrs
(Water Well Contractor)

Contractor's License No. 456 Date 1-9, 1969