

RECEIVED

MORR 440
G-5609

dcb

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

JUL 22 1968 WATER WELL REPORT

STATE ENGINEER OF OREGON

State Well No. 1N/26-35

State Permit No. G-4370

(1) OWNER:

Name Fritz CUTS FORTH well #2
Address 172 p n e r, OR 904

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

14" Diam. from 0 ft. to 70 ft. Gage 2.50
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 16 ft. below land surface Date 6/13/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Columbia
1: gal./min. with ft. drawdown after hrs.
" 1500 " 82' " 6 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 62 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 70' ft.
Diameter of well bore to bottom of seal 18 in.
Were any loose strata cemented off? Yes No
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MORROW Driller's well number
SW 1/4 SE 1/4 Section 35 T. 1 N. R. 26 E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 15" to 80" to 246'

Depth drilled 246 ft. Depth of completed well 246 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil light	0	8'	
BASALT FRACTURED Black BROWN with clay	8	46	
BASALT CINDERS Red-green	46	72	
BASALT BLACK	72	130	
" " FRACTURED w/ red cinders	130	143	
" grey (very hard)	143	190	
" BLACK FRACTURED w/ green soapstone	190	227	
" CINDERS Red	227	235	
BASALT, BLACK FRACTURED	235	246	

Water bearing

Water bearing

Work started 3/28 1968 Completed 6/24 1968
Date well drilling machine moved off of well 6/28 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Bill Rice Date 7/2/68, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 446

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Intervallley Drillings Co. (Type or print)

Address P.O. Box 471 Island City

[Signed] (Signature) (Water Well Contractor)

Contractor's License No. 388 Date 7/2/68, 1968