

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED JUL 29 1968 STATE ENGINEER SALEM OREGON

RECEIVED AUG 1 1968

Well # 2 MOR 480 166ct

State Well No. IN/27- State Permit No. G-4486

(1) OWNER: Healy Bros. Wm. J. & Tom

Name Healy Bros. Wm. J. & Tom Address Rt 2 Heppner, Oregon

(2) LOCATION OF WELL:

County Morrow Driller's well number 27 T. 1N R. 27 W.M. Bearing and distance from section or subdivision corner Mr. Healy says this well is in Section 26. The land to be sprinkled is in Section 27.

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandonment

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

None Threaded Welded Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal not disturbed Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes No Was well gravel packed? Yes No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 50 ft. below land surface Date 7-16-68 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yes No If yes, by whom Columbia Pump Yield: 900 gal./min. with 98 ft. drawdown after 24 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 58° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 12" Depth drilled 250 ft. Depth of completed well 250 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Rock, grey (133-182), Rock, brown & black - water (182-185), Rock, grey, hard (185-214), Rock, blue, medium (214-228), Rock, grey, hard (228-232), Rock, brown & black, soft-water (232-236), Grey rock, hard (236-250)

Work started Jun 4 1968 Completed Jul 16 1968 Date well drilling machine moved off of well Jul 24 1968

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Hershey Well Drilling (Person, firm or corporation) (Type or print)

Address Rt 3, Box 343, Hermiston, Oregon

Drilling Machine Operator's License No. 143

[Signed] John Hershey (Water Well Contractor)

Contractor's License No. 315 Date July 24 1968