

MORR 56531

RECEIVED

APR 9 1999

STATE OF OREGON WATER SUPPLY WELL REPORT

WATER RESOURCES DEPT. SALEM, OREGON

WELL I.D. # L 27925 START CARD # 63077 102730

Instructions for completing this report are on the last page of this form.

(1) OWNER: Name Part of Morrow Address PO 200 City Boardman State OR Zip 97818

(2) TYPE OF WORK: [] New Well [] Deepening [X] Alteration (repair/recondition) [] Abandonment

(3) DRILL METHOD: [X] Rotary Air [] Rotary Mud [] Cable [] Auger [] Other

(4) PROPOSED USE: [] Domestic [] Community [] Industrial [X] Irrigation [] Thermal [] Injection [] Livestock [] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [X] Yes [] No Depth of Completed Well 946

Table with columns: Diameter, From, To, Material, From, To, Sacks or pounds. Row 1: 16, 0, 942, cement, 410, 445, 108 SKS

How was seal placed: Method [] A [X] B [] C [] D [] E Backfill placed from ft. to ft. Material Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Row 1: Casing 16, 0, 942, 250, [X], [], [], []

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Row 1: 601, 602, 1x6, 4, [], [], [], [X]

(8) WELL TESTS: Minimum testing time is 1 hour. [] Pump [] Bailer [X] Air [] Artesian Yield gal/min 2000x Drawdown Drill stem at 944 Time 1 hr.

Temperature of water 72 Depth Artesian Flow Found Was a water analysis done? [] Yes By whom Did any strata contain water not suitable for intended use? [] Too little [] Salty [] Muddy [] Odor [] Colored [] Other Depth of strata:

(9) LOCATION OF WELL by legal description: County Morrow Latitude Longitude Township 4 N or S Range 24 E or W. WM. Section 22 NW 1/4 SW 1/4 Tax Lot 109 Lot Block Subdivision Street Address of Well (or nearest address) 1/2 mile west of Tower Rd. Boardman OR

(10) STATIC WATER LEVEL: 54 ft. below land surface. Date 4-31-99 Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES: Depth at which water was first found 485

Table with columns: From, To, Estimated Flow Rate, SWL. Row 1: 485, 942, 2000 x, 54

(12) WELL LOG: Ground Elevation

Table with columns: Material, From, To, SWL. Row 1: Pressure cemented Bottom of 16" casing at 430

Date started 3-1-99 Completed 3-30-99 (unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

WWC Number Signed Date

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

WWC Number 759 Signed J. Brown Date 3-31-99