

RECEIVED

MORR 50799

STATE OF OREGON WATER SUPPLY WELL REPORT

DEC 26 2000

(as required by ORS 537.765)

Instructions for completion are on the last page of this form.

MORR 50799

WELL I.D. # L 43418 START CARD # 130175

(1) LAND OWNER: JOHN VAUNDERBRINK, Address: 4661 China Ave, City: China, State: CA, Zip: 91710

(2) TYPE OF WORK: [X] New Well, [] Deepening, [] Alteration, [] Abandonment

(3) DRILL METHOD: [X] Rotary Air, [] Rotary Mud, [] Cable, [] Auger

(4) PROPOSED USE: [] Domestic, [] Community, [] Industrial, [X] Irrigation

(5) BORE HOLE CONSTRUCTION: Special Construction approval [] Yes [X] No, Depth of Completed Well 1180 ft.

Table with columns: Diameter, From, To, Material, From, To, Sack or pounds. Includes data for 17/2, 14 3/4, 10 inch diameters and PORT CEMENT material.

How was seal placed: Method [] A [] B [X] C [] D [] E

Backfill placed from ___ ft. to ___ ft. Material ___

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Includes data for 16 inch casing.

Drive Shoe used [] Inside [X] Outside, [] None

(7) PERFORATIONS/SCREENS: Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. Table with columns: Yield gal/min, Drawdown, Drill stem at, Time. Includes data for 1000 gal/min yield.

Temperature of water 74 °F, Depth Artesian Flow Found ___, Was a water analysis done? [] Yes [] No

(9) LOCATION OF WELL by legal description: County Morrow, Township 1, Range 24, Section 28, Tax Lot 3501

(10) STATIC WATER LEVEL: 471 ft. below land surface

(11) WATER BEARING ZONES: Depth at which water was first found 620'

Table with columns: From, To, Estimated Flow Rate, SWL. Includes data for 620-642, 934-951, 1065-1085, 1144-1165.

(12) WELL LOG: Ground Elevation ___, JUL 30 2001

WELL LOG table with columns: Material, From, To. Lists layers like SOIL, CEMENT GRAVEL, BRN TAN CLY STONE, BLK BRN BASALT, etc.

Date started 7-19-00, Completed 10-27-00

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.

DEC 26 2000

MORR 50799

STATE OF OREGON WATER SUPPLY WELL WATER RESOURCES DEPT. SALEM, OREGON

MORR 50799

WELL I.D. # L 43418 START CARD # 130175

Instructions for completing this report are on the last page of this form.

(1) LAND OWNER Name Vandenbrink Address 6661 Chesnut City Chino State CA Zip 91716

(2) TYPE OF WORK New Well Deepening Alteration Abandonment

(3) DRILL METHOD: Rotary Air Rotary Mud Cable Auger Other

(4) PROPOSED USE: Domestic Community Industrial Irrigation Thermal Injection Livestock Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval Yes No Depth of Completed Well Explosives used Yes No Type Amount

Table with columns for HOLE Diameter, From, To, Material, SEAL From, To, Sacks or pounds

How was seal placed: Method A B C D E Backfill placed from ft. to ft. Material Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns for Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded

Drive Shoe used Inside Outside None Final location of shoe(s)

(7) PERFORATIONS/SCREENS: Table with columns for From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner

(8) WELL TESTS: Minimum testing time is 1 hour. Table with columns for Pump, Bailer, Air, Artesian, Yield gal/min, Drawdown, Drill stem at, Time

Temperature of water Depth Artesian Flow Found Was a water analysis done? Did any strata contain water not suitable for intended use? Depth of strata:

(9) LOCATION OF WELL by legal description: County Morrow Latitude Longitude Township N or S Range 24 E or W. WM. Section 28 SW 1/4 SE 1/4 Tax Lot 3501 Lot Block Subdivision Street Address of Well

(10) STATIC WATER LEVEL: 471 ft. below land surface. Artesian pressure lb. per square inch

(11) WATER BEARING ZONES: Depth at which water was first found

Table with columns for From, To, Estimated Flow Rate, SWL

RECEIVED

(12) WELL LOG: Ground Elevation JUL 30 2001

WELL LOG table with columns for Material, From, To

Date started 7-19/00 Completed 10/27/00

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Signed Rusty Otto WWC Number 1702 Date 10/27/00

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. Signed Tony Burt WWC Number 544 Date 10-27-00