

STATE OF OREGON WATER SUPPLY WELL REPORT

MORR 51948



WELL LABEL # L 54975 START CARD # 1015371 ORIGINAL LOG # NA

(ORS 537.765 & OAR 690-205-0210)

Instructions for completing this report are on the last page of this form.

(1) LANDOWNER: Owner Well I.D. N/A, First Name City of Heppner, Last Name, Company, Address 111 N. Main St., P.O. Box 756, City Heppner, State Or., Zip 97836

(2) TYPE OF WORK: Alteration (complete Sections 2a & 10)

(2a) PRE-ALTERATION: Well Depth 159' ft., Seal Material, Casing Type: Steel, Casing Gauge N/A, Casing Diameter 10" to 47"

(3) DRILL METHOD: Cable

(4) PROPOSED USE: Community

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 159' ft. Special Standard: Yes

Table with columns for Bore Hole (Dia, From, To, Material, Amount, Scks/lbs) and SEAL (From, To, Amount, Scks/lbs)

How was seal placed: Method A, B, C, D, E. Other: Used cementing shoe @ 90' + circulate to surface

(5a) ABANDONMENT USING UNHYDRATED BENTONITE: Calculated Amount Proposed to be Used, Actual Amount Used

(6) CASING/LINER: Table with columns for Casing/Liner type, Dia, Gauge, Steel, Plastic, Welded, Thrd

Shoe: Inside, Outside, Other. Location of shoe(s), Temporary casing: Yes, Diameter, From, To

(7) PERFORATIONS/SCREENS: Table with columns for Perf, Scrn, Casing, Liner, Screen Dia, From, To, Screen slot width, Slot length, # of slots, Tele/pipe size

(8) WELL TESTS: Minimum testing time is 1 hour. Pump, Bailer, Air, Flowing Artesian. Yield gal/min 30, Drawdown 0', Duration 1.5 hr, Temperature 65°F

(9) LOCATION OF WELL (legal description): County Morrow, Twp 2, Range 27, Sec 31 S.E. 1/4 of the S.E. 1/4 Tax Lot 26-4301. Street Address of Well (or nearest address) off Willow Cr. Rd.

(10) STATIC WATER LEVEL: Table with columns for Date, SWL (psi), SWL (ft) for Existing Well/Pre-Alteration and Completed Well

WATER BEARING ZONES: Table with columns for SWL Date, From, To, Est Flow, SWL (psi), SWL (ft)

(11) WELL LOG: Table with columns for Material, From, To, Ground Elevation

RECEIVED DEC 27 2011 WATER RESOURCES DEPT SALEM, OREGON

Date Started 11/09/2011 Completed 11/23/2011

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.

License Number 1769 Date 12/22/2011 Signed Kelly Olson

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above.

License Number 1669 Date 12-22-11 Signed Jody Chapman