NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date MORK 57

WATER WELL REPORT

STATE OF OREGON

OCT 1 0 1973 state Well No.

(Please type or print) STATE ENGINEER State Permit No. (Do not write above this line) SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:	-		
Name Town of Lexington	County Morrow Driller's well number			
Address Lexington, Or. 97839	SW 1/4 SE 1/4 Section 34 T. 15	R. 25	E.	W.M.
(a) MADE OF MODIL (1 1)	Bearing and distance from section or subdivisi			
(2) TYPE OF WORK (check):	N. 14 15' E. from S4 cr: of Se	ection ?	34 , I	115
New Well ☒☒ Deepening ☐ Reconditioning ☐ Abandon ☐	R 25 E.W.M. 830			····
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	380		ft.
Rotary Driven Domestic Industrial Municipal 🔼	Static level 150 ft. below land s	surface. Da	te 9 (et 72
Dur	Artesian pressure lbs. per squar			
(5) CASING INSTALLED: Threaded Welded 15 Welded 15 Gage • 250 ft. to Diam. from ft. to ft. Gage • 250 ft. Gage	(12) WELL LOG: Diameter of well I Depth drilled 528 ft. Depth of compl		g	12
" Diam. from ft. to ft. Gage PERFORATIONS: Perforated? Yes No.	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.			
Type of perforator used	MATERIAL	From	то	SWL
Size of perforations in. by in.	Top Soil	0	2	
perforations fromft. toft.	Cement Gravel	2	19	
perforations fromft. toft.	Brown Clay and Gravel		163	
perforations from ft. to ft.	Blue Basalt Rock		276	
(7) SCREENS: Well screen installed? If Yes X No.	Brown Basalt Rock		361	
West between substances. In teb 45 176	Hard Gray Basalt Rock		380	
Manufacturer's Name	Black Broken Basalt		394	219
Diam. Slot size Set from ft. to ft.	Blue Basalt Rock		473	
Diam, Slot size Set from ft. to ft.	Hard Gray Basalt Porous Black Basalt		492 524	150
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Hard Gray Basalt		528	
Was a pump test made? Yes No If yes, by whom? driller				
200 gal./min. with 250 ft. drawdown after 8 hrs.				
" " "				
" " "				
Bailer test gal./min. with ft. drawdown after hrs.	· · · · · · · · · · · · · · · · · · ·			
4 / 1 / 2		<u> </u>		
perature of water 68 Depth artesian flow encountered	O T7 570	11 00		70
perature of water 68 Depth artesian flow encountered It.		ed 11 Oc		1972
(9) CONSTRUCTION:	Date well drilling machine moved off of well	26 Nov		1972
Well seal—Material used Cement Well sealed from land surface to 202 ft. Diameter of well bore to bottom of seal 16 in.	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.			
Diameter of well bore below seal12 in. Number of sacks of cement used in well seal 6 yards	[Signed] (Brilling Machine Operator) Date 7 Oct , 1973			
Secretary Secret	Drilling Machine Operator's License No. 138			
Number of sacks of bentonite used in well sealsacks Brand name of bentonite				
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:			
of waterlbs./100 gals.	This well was drilled under my jurisdi	ction and	this re	port is
Was a drive shoe used? XYes 🗌 No Plugs Size: location ft.	true to the best of my knowledge and belief. Name Thomas R. Ruther			
Did any strata contain unusable water? 🗌 Yes 🔼 No	(Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address 1421) Circle Divive; Wal	la Wall	a, W	a 993
Method of sealing strata off	[Signed] A 3 and A All			
Was well gravel packed? ☐ Yes 🏋 No Size of gravel:	[Signed] Manday Water Well Contr.	actor)		
Gravel placed from ft. to ft.	Contractor's License No. 374 Date 7	Oct.		19 73
	(FERS IF NECESSARV)			, 19;.;;