

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

RECEIVED

FEB 17 1978

State Well No. 3M/26E-322

State Permit No.

WATER RESOURCES DEPT.

MOOR 589

(1) OWNER:

Name U.B. S. Farms  
Address Rt 1 Box 518  
Nyasa Oregon 97913

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 138 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " " "  
air test 42 " 166 " 1 "  
air test 30 gal./min. with 72 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to 138 ft.  
Diameter of well bore to bottom of seal 9 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 16 sacks  
How was cement grout placed?  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Morrow Driller's well number  
NE 1/4 NE 1/4 Section 3 T. 37, R. 26 E. W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 120 ft.  
Static level 148 ft. below land surface. Date 2-9-78  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"  
Depth drilled 324 ft. Depth of completed well 324 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sand	0	117	
Gravel + light brown claystone	117	126	
Claystone, brown	126	129	
Rock, med. block	129	139	
Basalt, black	139	151	
Rock, med. brown	151	172	
Claystone, gray	172	190	
Claystone, light brown	190	194	
Claystone, white	194	200	
Rock, med. red	200	211	W.B.
Basalt, black	211	282	
Basalt, hard, gray	282	296	
Basalt, gray w/ claystone	296	310	W.B.
Rock, brown w/ gray claystone	310	324	W.B.

Work started 2-7 1978 Completed 2-10 1978  
Date well drilling machine moved off of well 2-10 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Small O'Shane Date 2-10, 1978  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1210

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name TRAY GRIFFIN (Type or print)  
Address 900 HERMISTON AVE  
[Signed] Tray Griffin (Water Well Contractor)

Contractor's License No. 65 Date 2-10, 1978