

RECEIVED

MORROW

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

SEP 20 1967 WATER WELL REPORT STATE ENGINEER STATE OF OREGON SALEM, OREGON (Please type or print)

State Well No. 3 N/27-4 H
State Permit No.

(1) OWNER:

Name CLARK + Bernice Key
Address Route # 1 Box 184A
HERMISTON - OREGON

(2) LOCATION OF WELL:

County MORROW Driller's well number 8
SE 1/4 NW 1/4 Section 4 T. 3 R. 27N W.M.
Bearing and distance from section or subdivision corner
FROM NE CORNER of section 4
South 1980 Feet West 780 Feet

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 60 ft. Gage 1/4"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used FORCH
Size of perforations 1/4 in. by 6 in.
perforations from 22 ft. to 53 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 28 ft. below land surface Date 9/25/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? Clark Key
Yield: 200 gal./min. with 20 ft. drawdown after 10 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 180 ft. Depth of completed well 180 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include top soil, SAND AND GRAVEL, CLAY, BASALT, CLAY, BROKEN BROKEN BASALT, CLAY INTER BEDDED BASALT.

Work started JUNE 1 1967 Completed September 19 67
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: Clark Key (Person, firm or corporation)
Address Hermiston OR PT 1 # 184A
Drilling Machine Operator's License No. self
[Signed] (Water Well Contractor)
Contractor's License No. Date , 19