

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

RECEIVED

State Well No. 15/26K-1
State Permit No.

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

MORR 63

JAN 19 1977

(Do not write above this line)

WATER RESOURCES DEPT.

(1) OWNER:

Name FRITZ CUTSFORTH
Address HOPNER ORP

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

12" Diam. from ±2 ft. to -28 ft. Threaded Welded Gage 250
....." Diam. from ft. to ft. Gage
....." Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Type Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water 38° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 28' ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 19 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County MORROW Driller's well number
SW 1/4 SE 1/4 Section 1 T. 15 R. 26E W.M.
Bearing and distance from section or subdivision corner

SW 1/4 SE 1/4

(11) WATER LEVEL: Completed well.

Depth at which water was first found 65 ft.
Static level ~~030~~ 26 ft. below land surface. Date 12-12-76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled 250 ft. Depth of completed well ~~675~~ 250 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	3	
SOIL & BOLDERS	3	12	
BASALT BLACK BROKEN	12	15	
" BLACK	15	72	106
11" BLACK SCORIA	72	80	506
" BLACK	80	87	
4" BLACK SCORIA & GREEN CLAYSTONE LAYERS	87	250	500+

Work started 12-1 76 19 Completed 12-12 1976
Date well drilling machine moved off of well 12-12 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jay Burd Date 12-12, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 933

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name LARRY BURD WELL DRILLING
(Person, firm or corporation) (Type or print)

Address 5543 S.W. DOUGLASS DR.

[Signed] Jay Burd
(Water Well Contractor)

Contractor's License No. 544 Date 12-12, 1976