

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

**RECEIVED**

**WATER WELL REPORT**

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

DEC 1 1978

STATE OF OREGON  
(Please type or print)

State Well No. 4N/24E-14C  
State Permit No. G-8763

RESOURCES DEPT  
SALEM, OREGON

(Do not write above this line)

*Implementation of Well Log # 98, dated Aug 4/78*

**(1) OWNER:**

Name W.C. Hendrix  
Address P.O. Box 25 Boardman Oregon 97818

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
Diam. from 7.5 ft. to 7.5 ft. Gage Installed  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

**(5) PERFORATIONS:**

Perforated?  Yes  No.  
Type of perforator used ✓  
Size of perforations ✓ in. by ✓ in.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name ✓  
Type ✓ Model No. ✓  
Diam. ✓ Slot size ✓ Set from ..... ft. to ..... ft.  
Diam. ✓ Slot size ✓ Set from ..... ft. to ..... ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Air test Held: 1000 gal./min. with 200 ft. drawdown after 1 1/2 hrs.  
Approx. 800 " 200 " 400 " 1/4 "  
Bailer test ✓ gal./min. with ✓ ft. drawdown after ..... hrs.  
Artesian flow NONE g.p.m. ✓  
Temperature of water 58 Depth artesian flow encountered NONE ft.

**(9) CONSTRUCTION:**

Well seal—Material used Previously sealed  
Well sealed from land surface to ..... ft.  
Diameter of well bore to bottom of seal ..... in.  
Diameter of well bore below seal ..... in.  
Number of sacks of cement used in well seal ..... sacks  
How was cement grout placed? ✓  
Was a drive shoe used?  Yes  No Plugs ✓ Size: location ..... ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? ✓ depth of strata ✓  
Method of sealing strata off ✓  
Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.

**(10) LOCATION OF WELL:**

County Morrow Driller's well number 98  
SW 1/4 SW 1/4 Section 14 T. 4N R. 24E W.M.  
Bearing and distance from section or subdivision corner  
1250' E, S 1250 N. of S.W. corner  
of Sec. 14

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found originally 12.0 ft.  
Static level 6.5 ft. below land surface. Date Nov. 28/78  
Artesian pressure NONE lbs. per square inch. Date Nov. 28/78

**(12) WELL LOG:**

MATERIAL	From	To	SWL
<u>Hard Black Basalt</u>	<u>195.0</u>	<u>292.0</u>	<u>9.0</u>
<u>Blue clay Interbed</u>	<u>292.0</u>	<u>440.0</u>	<u>39.0</u>
<u>Viscous Basalt with</u>	<u>440.0</u>	<u>534.0</u>	<u>39.0</u>
<u>Blue clay</u>		<u>534.0</u>	<u>65.0</u>
<u>Hard Black Basalt</u>	<u>534.0</u>	<u>541.0</u>	<u>65.0</u>

Work started Nov. 6 19 78 Completed Nov. 29 19 78  
Date well drilling machine moved off of well Nov. 29 19 78

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Edwin E. Brown Date Nov. 29, 1978  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 153

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Brown & Brown Drilling Co.  
(Person, firm or corporation) (Type of print)  
Address P.O. Box 124, Hermiton  
[Signed] John L. Brown Oregon 97838  
(Water Well Contractor)  
Contractor's License No. 516 Date Nov. 29, 19 78