

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MORR 746

State Well No.

State Permit No.

4N/25-96(11) ac

(1) OWNER:

Name BOARDMAN CEMETERY ASSN.
Address BOARDMAN OREGON

(2) LOCATION OF WELL:

County MORROW Driller's well number _____
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
RIVERVIEW CEMETERY

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
1.2" Diam. from 0 ft. to 72.5 ft. Gage 5/8 x 1/40
1.0" Diam. from 12.5 ft. to 193 ft. Gage 5/8 x 40
8" Diam. from 0 ft. to 44.5 ft. Gage 5/8 x 40

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Slotted w/ acceptor tool
Size of perforations 1/4" in. by 8 in.
perforations from _____ ft. to _____ ft.
Bottom 76 ft. by 8" pipe
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name JOHNSON
Model No. _____
L 4" Slot size 29 Set from 43.5 ft. to 46.5 ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal 12" CASING
Depth of seal 7.2 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 1.2 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No Crushed rock used
Was well gravel packed? Yes No Size of gravel: 10 x 16
306 Gravel placed from 440 ft. to 470 ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off Blue Clay

(10) WATER LEVELS:

Static level 58 ft. below land surface Date 8-15-64
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? Iller
Yield: 175 gal./min. with 165 ft. drawdown after 72 hrs.
" " " " " "
" " " " " "
Bailer test 9 gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 58 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 470 ft. Depth of completed well 470 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SAND & GRAVEL	0	72
Basalt	72	140
CLAY	140	185
BRECCIA	185	209
BASALT	209	390
BLUE CLAY	390	435
CLAY w/ SAND	435	440
UNUSUAL BASALT	440	470
MEDIUM SAND		

Work started Job 3 1964 Completed Aug 15 1964
Date well drilling machine moved off of well Aug 15 1964

(13) PUMP:

Manufacturer's Name Jeco 331
Type: TURBINE H.P. ✓

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.R. IIP (Person, firm or corporation) (Type or print)

Address 3401 NE 130 AVE PORTLAND

Drilling Machine Operator's License No. 299

[Signed] W.R. Iller (Water Well Contractor)

Contractor's License No. 405 Date 15 Oct, 1964