

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
STATE ENGINEER
SALEM OREGON

SEP 30 1968

STATE OF OREGON
 (Please type or print)
 (Do not write above this line)

MARR 800

State Well No. 4N/25-14

State Permit No. _____

(1) OWNER:

Name GEORGE SICARD & SON
 Address Rt 1 Box 60 BOARDMAN ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 36 ft. Gage 250
6" Diam. from 217 ft. to 337 ft. Gage 250
 _____" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations	in.	by	in.
_____ perforations from _____	_____	_____	_____
_____ perforations from _____	_____	_____	_____
_____ perforations from _____	_____	_____	_____
_____ perforations from _____	_____	_____	_____
_____ perforations from _____	_____	_____	_____

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 00 ft. below land surface Date _____
 Artesian pressure 1 lbs. per square inch Date 9-19-68

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____

Field:	gal./min. with	ft. drawdown after	hrs.
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Bailer test 50 gal./min. with 10 ft. drawdown after 1 hrs.
 Artesian flow 5 g.p.m. Date 7-29-68
 Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE CLAY
 Depth of seal 18 ft.
 Diameter of well bore to bottom of seal 16 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County MORROW Driller's well number _____
SE 1/4 Section 14 T4N R. 25E W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 12
 Depth drilled 112 ft. Depth of completed well 382 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Silt & Sand	0	25	NO
SAND & GRAVEL	25	31	
WEATHERED BASALT	31	36	
DENSE BASALT	36	62	
Flow Breccia	62	70	Art. Flow
Blue Clay	70	95	0
vesicular BASALT	95	112	0
Reduced Hole to 8" @	112		0
DENSE BASALT	112	247	0
Blue Clay	247	337	0
Med. Hard BASALT	337	362	0
Blue Clay	362	382 T.D.	

Work started 7-25 1968 Completed 9-19 1968
 Date well drilling machine moved off of well 9-19-68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] St. R. Allen Date 9-20, 1968
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 299

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.R. T. I. I. E.
 (Person, firm or corporation) (Type or print)

Address 2731 NE 132 AVE PORTLAND

[Signed] St. R. Allen
 (Water Well Contractor)

Contractor's License No. 405 Date 9-20, 1968