NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

MORR 951

RECEIVED
SEP 25 1973
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)
G-5549 Well No. 3

State Well No. 4N/27E-28 6
State Permit No. 54

(1) OWNER:
Name Jedediah Aylett
Address Rt. 1 Box 281 Hermiston, Oregon 97838

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
16" Diam. from ft. to 110 ft. Gage .025 Wall
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Knife
Size of perforations 3/16 in. by 2 in.
240 perforations from 85 ft. to 100 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to app. 18 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal — sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite Yellow Stone Western Bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plug Concrete: location 100 ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata 77 ft
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 2 1/2 Minus
Gravel placed from 0 ft. to 100 ft.

(10) LOCATION OF WELL:
County Morrow Driller's well number
NW ¼ ¼ Section 28 T. 4N R. 27 East W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 77 ft.
Static level 77 ft. below land surface. Date Aug 7, 1973
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 16"
Depth drilled 110 ft. Depth of completed well 101 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top Soil (Sand)	0	3	
Pea gravel	3	10	
Fine gravel to Coarse Rock	10	110	
at 65 feet there was 6" of hard claleche.			

Work started July 21 1973 Completed Sept 8 1973
Date well drilling machine moved off of well Aug. 21 1973

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Self Drilled (Drilling Machine Operator) Date , 19
Drilling Machine Operator's License No.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name (Person, firm or corporation) (Type or print)
Address Rt. 1 Box 281 - Hermiston, Oregon 97838
[Signed] Jedediah M. Aylett (Water Well Contractor)
Contractor's License No. Date Aug 28, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119