

FARMORE DISTRIBUTING COMPANY

BOX 327 ATHENA, OREGON

WELL TEST LOG

Test Number Hermiston

Place Jeddie Aylett

Pump Setting 110' plus bowls

Air Line 100'

Well Depth 122'

Date 3/7/72

Well Size 15"

Static Level 72'

MORR 953

START TIME	RPM CHECK	GPM READING	AIRLINE READING	ORIFICE READING	DROP PIPE	MAKE	SIZE	PUMP INSTALLED		WATER CONDITIONER
								SERIAL	MODEL	
1:15	1300	1455	8# 82' to water							Muddy
1:25	1600	1879	12#	36"	28' lift on air line					
1:35	1800	2050	11#							Clear
1:40	2000	2350	81' to water	54 to 55"						Clear
2:00	2000	2350	81' to water	54/55						Clear
2:30	2000	2350	81'	54/55						Clear
3:00	2000	2350	81'	54/55						Clear
3:30	2000	2350	81'							
4:00	2000	2350	81'							
4:30	2000	2350	81'							
5:00	2000	2350	81'		Shut down					Clear

DECEASED
MAY 24 1972
STATE ENGINEER
SALEM OREGON