

W. PARK RECEIVED WATER WELL REPORT NOV 3 1960 STATE OF OREGON MULT 1007

State Well No. IN/1-23 D (1)  
State Permit No. G1362

(1) OWNER: STATE ENGINEER SALEM, OREGON  
Name Fred Meyer  
Address 721 S. W. 4th Ave. Portland, Oregon

(2) LOCATION OF WELL:  
County Multnomah Owner's number, if any—  
NW ¼ NW ¼ Section 23 T. 1 N R. 1 E W.M.  
Bearing and distance from section or subdivision corner  
230 ft. S and 45 Ft. E from the NW corner of Sec. 23 1N 1E

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 200 gal./min. with 1 ft. drawdown after 8 hrs.  
" 300 " " 2 1/2 " " 8 "  
" 370 " " 4 " " 8 "  
Bailer test 70 gal./min. with 0 ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 54.5 Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well 12 inches.  
Depth drilled 326 ft. Depth of completed well 326 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Loose sand and gravel	surface	29
Sand and gravel - some clay binder	29	47
Coarse sand and some gravel	47	79
Gravel - some clay binder	79	138
Loose gravel, sand, boulders	138	187
Sand, gravel and clay	187	206
Water bearing sand and gravel	206	217
Cemented gravel	217	289
Water bearing sand and gravel	289	318
Sand, gravel, and clay	318	326

TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

12" Diam. from surface ft. to 326 ft. Gage 43.771  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Star  
SIZE of perforations 3/8 in. by 1 1/4 in.  
360 perforations from 205 ft. to 214 ft.  
400 perforations from 202 ft. to 302 ft.  
320 perforations from 306 ft. to 314 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

CONSTRUCTION:

Well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Was a surface seal provided?  Yes  No To what depth? 40 ft.  
Material used in seal— cement grout  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 180 ft. below land surface Date July 13, 1960  
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Fred Meyer, Jr. date 10/21, 1960  
(Owner)

Work started May 27 19 60 Completed July 14 19 60

(13) PUMP:

Manufacturer's Name Peerless  
Type: Deep Well Turbine H.P. 30

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. STRASSER DRILLING CO.  
(Person, firm, or corporation) (Type or print)

Address 8110 S. E. Sunset Lane, Portland 6

Driller's well number 4021

[Signed] Robert J. Strasser  
(Well Driller)

License No. 10 Date August 15, 1960