

OBSERVATION WELL

1038
MULT.

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

Record from
Well Registration
No. GR-3607

WATER WELL REPORT
STATE OF OREGON

State Well No. 1N/1-330(1)

State Permit No. Pg 1 of 5

(1) OWNER:

Name United States National Bank
Address Stadium Branch
2000 SW Morrison Portland, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any—
SE 1/4 SW 1/4 Section 33 T. 1 N R. 1 E W.M.
Bearing and distance from section or subdivision corner
Block 1, Russel Addition

Elevation 115

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8 " Diam. from 0 ft. to 203 ft. Gage
6 " Diam. from 164 ft. to 428 ft. Gage
" Diam. from _____ ft. to _____ ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 100 ft. below land surface Date 1946
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____
Yield: 65 gal./min. with 75 ft. drawdown after _____ hrs.
" 100 " " 140 " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8-6 inches.

Depth drilled 563 ft. Depth of completed well 563 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
sand	0	40
gravel, loose	40	116
gravel, cemented	116	128
sand and gravel	128	148
gravel, cemented	148	177
sand	177	181
gravel, cemented	181	228
lava rock	228	300
lime rock	300	317
rock, hard black	317	354
rock, broken some shale	354	390
lava rock, small amount of water	390	403
sand, black	403	425
conglomerate, rock and clay	425	455
basalt rock	455	480
lava rock	480	488
basalt rock	488	563

Work started May 1946 Completed July 1946

(13) PUMP:

Manufacturer's Name F. M. Pomona
Type: Turbine H.P. 15

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME _____
(Parson, firm, or corporation) (Type or print)
Address _____
Driller's well number _____
[Signed] _____
(Well Driller)
License No. _____ Date _____, 19____

STATE ENGINEER
Salem, Oregon

MULT
1038

Well Record

STATE WELL NO. 1N/1-33
COUNTY Multnomah
APPLICATION NO. GR-3607

OWNER: Stadium Branch of U.S. National Bank of Portland

MAILING ADDRESS: 2000 S.W. Morrison

LOCATION OF WELL: Owner's No. _____

CITY AND STATE: Portland, Oregon **P 3 of 5**

Russell Addition
_____ 1/4 _____ 1/4 Sec. 33 T. 1 N. S. R. 1 E. W.M.

Bearing and distance from section or subdivision corner 45' S. & 5' W from NE Cor. of Block 1, Lot 8

Section _____

Altitude at well _____

TYPE OF WELL: drilled Date Constructed 1946

Depth drilled 563' Depth cased 428'

CASING RECORD:

8" and 6"

FINISH:

AQUIFERS:

sand, gravel, rock, shale, clay, basalt rock

WATER LEVEL:

100'

PUMPING EQUIPMENT: Type Fairbanks Morse H.P. 15
Capacity 100 G.P.M.

WELL TESTS:

Drawdown 240 ft. after _____ hours pumping 100 G.P.M.
Drawdown 175 ft. after _____ hours pumping 65 G.P.M.

USE OF WATER air-conditioning Temp. _____ °F. _____, 19_____

SOURCE OF INFORMATION GR-3155

DRILLER or DIGGER _____

ADDITIONAL DATA:

Log Water Level Measurements _____ Chemical Analysis _____ Aquifer Test _____

REMARKS:

