

MULT 1064

WATER WELL REPORT

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

Record from well registration No. GR-2673 & U.S.G.S. STATE OF OREGON

State Well No. 1N/1-34N(4)

State Permit No.

(1) OWNER:

Name Equitable Savings & Loan Assoc. Address 411 SW 6th Ave. Portland, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any- 2 SW 1/4 SW 1/4 Section 34 T. 1 N R. 1 E W.M. Block 176, Portland

Bearing and distance from section or subdivision corner elevation 38 feet

(3) TYPE OF WORK (check):

New Well [] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [] Industrial [x] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [] 14" Diam. from 0 ft. to 163 ft. Gage 12" Diam. from 163 ft. to 370 ft. Gage

(7) PERFORATIONS:

Perforated? [] Yes [x] No Type of perforator used SIZE of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [] Yes [] No To what depth? ft. Material used in seal- Did any strata contain unusable water? [] Yes [] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 36 ft. below land surface Date Dec. 1946 Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Date 19 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: 700 gal./min. with 32 ft. drawdown after hrs.

(12) WELL LOG:

Diameter of well 14-12 inches. Depth drilled 508 ft. Depth of completed well ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include sand and gravel, clay, clay with sand, etc.

Work started Nov. 16 1946. Completed Dec. 16 1946

(13) PUMP:

Manufacturer's Name Peerless 600 gpm Turbine H.P. 20

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. Janssen Drilling Co. (Person, firm, or corporation) (Type or print)

Address Reedville

Driller's well number

[Signed] (Well Driller)

License No. Date 19

STATE ENGINEER
Salem, Oregon

State Well No. LN/1-34N(4)

County Multnomah

Application No.

Chemical Analysis

OWNER Equitable Savings & Loan Assoc OWNER'S NO. 2

ANALYST Charlton Laboratories Address Portland

Date of Collection 1-9-47

Point of Collection

	P.P.M.	E.P.M.
Silica (SiO ₂)	35	
Iron (Fe) Total	.2	
Manganese (Mn)		
Calcium (Ca)	45	
Magnesium (Mg)	1.8	
Sodium (Na) + Potassium (K) as Na	174	
Potassium (K)		
Bicarbonate (HCO ₃)		
Carbonate (CO ₃)		
Sulfate (SO ₄)	13	
Chloride (Cl)	308	
Fluoride (F)		
Nitrate (NO ₃)		
Boron (B)		
Dissolved Solids		
Hardness as CaCO ₃	119	
Specific Conductance (Micromhos at 25°C)		
pH	7.8	
Percent Sodium		
Sodium Absorption Ratio (S.A.R.)		
CLASS		

STATE ENGINEER
Salem, Oregon

State Well No. *1N/1-34N4*

County *Multnomah*

Application No. _____

Water Level Record

OWNER: *Equitable Bldg.* OWNER'S NO. *#2*

Description of measuring point: _____

Electrical Conductivity in micromohs at 25°C

Date	EC Water Level ft (above) (below) Land Surface	Remarks	Date	Water Level Feet (above) (below) Land Surface	Remarks
<i>4-¹⁹-61</i>	<i>570</i>	<i>WSB P.O. Recharging # # 1.3.3.</i>			
<i>7-18-61</i>	<i>502</i>	<i>WSB P.O. " "</i>			
<i>10-9-61</i>	<i>500</i>	<i>WSB P.O. " "</i>			

REMARKS: _____

STATE ENGINEER
Salem, Oregon

State Well No. 1N/1-34N/4

County Multnomah

Application No. _____

Water Level Record

OWNER: Equitable Savings & Loan OWNER'S NO. #2

Description of measuring point: Well port pipe on west side of well + 9.0 feet below

LSD M.P. Elev. 8.98 feet used by Bldg. Engnr.

8 AM Date <i>Sunday</i>	Water Level Feet (above) Land Surface	Remarks	Date	Water Level Feet (above) Land Surface	Remarks
		<i>Temp after 10 min. Run</i>			
2-26-61	40.98	Temp 57°F WSB	7-2-61	45.98	Graham
3-5-61	42.10	" 56°F WSB	7-9-61	48.67	57°F
3-12-61	42.83	" 56°F	7-16-61	51.98	"
3-19-61	43.09	" "	7-23-61	50.98	
3-26-61	42.98		7-30-61	51.56	
4-2-61	43.93		8-13-61	54.68	
4-9-61	45.08		8-20-61	55.58	
4-16-61	44.04		8-27-61	52.78	
4-23-61	43.09	Graham 56°F	9-3-61	53.08	
4-30-61	45.74	" "	9-10-61	51.91	
5-7-61	44.78	" "	9-17-61	52.58	
5-14-61	42.88	" "	9-24-61	51.88	
5-21-61	43.92	Hot DAY " 56°F AM. & 62°F PM.	10-1-61	49.28	
5-28-61	41.38	" 56°F	10-8-61	41.91	
6-4-61	40.72	" "	10-10-61	78.0	PUMPING
6-11-61	39.08	" "	1-3-62	62.33	PUMPING
6-18-61	43.48	" "	10-15-61	52.78	
6-25-61	47.00	" "	10-22-61	51.28	

REMARKS: _____

Water Level Record

OWNER: Equitable Bldg. OWNER'S NO. _____

Description of measuring point: _____

Date	Water Level Feet (above) (below) Land Surface	Remarks	Date	Water Level Feet (above) (below) Land Surface	Remarks
9-16-62	50.78	Rpt.			
9-23-62	52.18				
9-30-62	54.78				
10-7-62	52.78				
10-14-62	48.78				

REMARKS: _____

STATE ENGINEER
Salem, Oregon

State Well No. 1N/1-34N4

County Multnomah

Application No. _____

Water Level Record

OWNER: Equitable Bldg. OWNER'S NO. #2

Description of measuring point: port pipe 9.0 feet below L.S.D.

Date	Water Level Feet (above) (below) Land Surface	Remarks	Date	Water Level Feet (above) (below) Land Surface	Remarks
10-29-61	50.08		4-15-62	45.68	
11-5-61	50.42		4-22-62	43.84	
11-12-61	50.18		4-29-62	44.28	
11-19-61	49.13		5-6-62	43.34	
11-26-61	48.28		5-13-62	41.98	
12-3-61	47.82		5-20-62	41.88	
12-10-61	50.38		5-27-62	41.78	
12-30-61	46.58		6-17-62	42.44	
1-3-62	62.33	Pumping	6-24-62	46.40	
1-14-62	45.23		7-1-62	46.48	
1-28-62	47.39		7-8-62	46.98	
2-4-62	32.63		7-15-62	46.08	
2-11-62	46.76		7-22-62	49.98	[Pump ran sat. Nitel]
2-18-62	44.08		8-5-62	50.38	
3-18-62	47.78		8-12-62	52.58	
3-25-62	44.68		8-19-62	52.88	
4-1-62	46.48		8-26-62	51.58	
4-8-62	45.88		9-9-62	51.93	

REMARKS: _____

