

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

MULT 1075

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 1N/1-34B

State Permit No.

(1) OWNER:

Name Memorial Colosseum Address Portland, Oregon

(2) LOCATION OF WELL:

County Mult Driller's well number 1/4 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] abandonment, describe material and procedure in Item 12,

(4) PROPOSED USE (check):

Domestic [] Industrial [X] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [] 14" Diam. from 0 ft. to 294.11 ft. Gage 1/2"

(7) PERFORATIONS:

Perforated? [] Yes [] No Type of perforator used Mills Knife Size of perforations 1/4" in. by 2" in. Heavy perforations from 225 ft. to 300 ft. Med perforations from 175 ft. to 225 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 70 ft. below land surface Date 7-25-59 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? B & S Yield: 1500 gal./min. with 100 ft. drawdown after 24 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 54° Was a chemical analysis made? [X] Yes [] No

(12) WELL LOG:

Diameter of well below casing 14" Depth drilled 300 ft. Depth of completed well 300 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Sandy Clay, Gravel, Muddy cement gravel, cement gravel, cement gravel sharp & muddy, S.L. 60, cement gravel soft & muddy, Hard cement gravel S.L. 80, muddy cement gravel, sandy gravel shows some water, cement gravel S.L. 70, fine sandy gravel show of water, cement gravel.

20 ft. screen #14 mesh 12 inch diam. Work started 6-1-59 19 Completed 7-25- 19 59 Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Barron & Strayer (Person, firm or corporation) (Type or print) Address Rt. 1, Box 254, Beaverton, Ore.

Drilling Machine Operator's License No.

[Signed] /s/ Lance Strayer (Water Well Contractor)

Contractor's License No. 35 Date Sept 8 19 59

RECEIVED
SEP 1 1960

WATER WELL REPORT
STATE OF OREGON

MULT
1079

State Well No. 1N/1-34B

State Permit No. _____

STATE ENGINEER
SALEM, OREGON

(1) OWNER:

Name Memorial Colossium
Address Portland Ore

(2) LOCATION OF WELL:

County Mult Owner's number, if any _____
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Industrial Municipal
 Test Well Other _____

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Wells Knife
SIZE of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
_____ Slot size _____ Set from _____ ft. to _____ ft.
_____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Casing placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal _____
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level _____ ft. below land surface Date 7-26-59
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? B & S
Yield: 1500 gal./min. with 100 ft. drawdown after 34 hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 14 inches.
Depth drilled 300 ft. Depth of completed well 300 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
sandy clay	0	15
GRAVEL	15	30
muddy cement gravel	30	40
CEMENT GRAVEL	40	52
CEMENT GRAVEL sharp & hard	52	115
" " some water	115	130
CEMENT GRAVEL soft & muddy	130	150
hard cement gravel Static 1.60	150	172
muddy cement gravel	172	200
sandy gravel shows some water	200	225
CEMENT GRAVEL	225	255
fine sandy gravel show of water	255	275
CEMENT GRAVEL	275	300

20# Screen #14 mesh
12 inch dia.

Work started 7-21-59 19____ Completed 7-25-59 19____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Barron & Strayer
(Person, firm, or corporation) (Type or print)
Address 55 I Box 251 Beaverton Ore

Driller's well number _____

[Signed] _____
(Well Driller) Sept 8 19____

License No. 35 Date _____, 19____

Jack,

I called Lou and Bill to day
and they are going to leave
your deposits and send them
to you and they would
notify me when they have
found they were sent to check
to put the proper property
description in and then
forward to you.

Looney