

RECEIVED
JUN 15 1966

MULT
1076

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

STATE ENGINEER, SALEM, OREGON
STATE ENGINEER, SALEM, OREGON
(Please type or print)

State Well No. 1N/1-34A
State Permit No. _____

(1) OWNER:

Name COLISEUM GARDENS
Address 1570 NE 2ND AVE
PORTLAND, ORE.

(2) LOCATION OF WELL:

County MULT. Driller's well number 4126
NE 1/4 NE 1/4 Section 2 T. 2S R. 1W W.M.
Bearing and distance from section or subdivision corner

34 1N-1E W/4

(3) TYPE OF WORK (check): WELL NO 2

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

17" Diam. from 0 ft. to 361 ft. Gage 330
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Star
Size of perforations 3/8 in. by 1/4 in.
480 perforations from 220 ft. to 228 ft.
720 perforations from 239 ft. to 251 ft.
840 perforations from 337 ft. to 351 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
Depth of seal 45-56 ft. Was a packer used? YES
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Do any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 118' 6" ft. below land surface Date 5/19/66
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 800 gal./min. with 35 ft. drawdown after 8 hrs.
" 500 " " 24 " " 10 "
" 350 " " 17 " " 12 "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 53 1/2 ° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 361 ft. Depth of completed well 361 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
BACKFILL	0	10
YELLOW SANDY CLAY	10	30
CLAY, SAND AND GRAVEL	50	67
LOOSE DRY GRAVEL	67	98
CLAY AND GRAVEL	98	132
SAND GRAVEL AND CLAY	132	180
BROWN SANDY SILT	180	202
CEMENTED GRAVEL	202	213
SAND AND GRAVEL (WATER)	213	252
CEMENTED GRAVEL	252	256
SAND AND GRAVEL (WATER)	256	274
CEMENTED GRAVEL	274	331
GRAVEL AND DIRTY SAND	331	339
SAND AND GRAVEL (WATER)	339	350
CEMENTED GRAVEL	350	361

Work started APR 11 1966 Completed MAY 24 1966
Date well drilling machine moved off of well MAY 24 1966

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME RS STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET AVE PORTLAND ORE.
Drilling Machine Operator's License No. 57 AND 54
[Signed] Robert L. Strasser
(Water Well Contractor)
Contractor's License No. 10 Date JUNE 13, 1966