

RECEIVED

MULT 1077

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER SALEM, OREGON (Please type or print)

State Well No. IN/1-34 A

State Permit No.

(1) OWNER:

Name COLISEUM GARDENS
Address 1520 NE 2ND AVE PORTLAND ORE.

(2) LOCATION OF WELL:

County MULT Driller's well number 4124
NE 1/4 NE 1/4 Section 2 T. 25 R. 100 W.M.
Bearing and distance from section or subdivision corner 34 IN 1E WR

(3) TYPE OF WORK (check): WELL NO. 1

New Well [] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [] Test Well [] Other [X]

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 249 ft. Gage 330
10" Diam. from 243 ft. to 332 ft. Gage 279

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used STAR WR
Size of perforations 3/8 in. by 1/4 in.
400 perforations from 168 ft. to 178 ft.
900 perforations from 227 ft. to 242 ft.
840 perforations from 295 ft. to 309 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
Depth of seal 45-61 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [] No Size of gravel:
Gravel placed from ft. to ft.
Do any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 118 ft. below land surface Date 4/4/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? STRASSER
Yield: 600 gal./min. with 101 ft. drawdown after 8 hrs.
" 500 " 102 " 10 "
" 354 " 69 " 12 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53 1/2 Was a chemical analysis made? [X] Yes [] No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 332 ft. Depth of completed well 332 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include SAND, SAND AND CLAY, CEMENTED GRAVEL, SAND AND LARGE GRAVEL, BROWN SAND, CEMENTED GRAVEL, SAND AND GRAVEL (WATER), LARGE GRAVEL SILT AND SAND, SAND AND GRAVEL (WATER), BLACK SAND, GREY SAND AND SILT, CEMENTED GRAVEL.

Work started FEB 17 1966 Completed APR 9 1966
Date well drilling machine moved off of well APR 9 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING Co
Address 8110 SE SUNSET LANE PORTLAND ORE
Drilling Machine Operator's License No. 57
[Signed] Robert L. Strasser
Contractor's License No. 10 Date JUNE 13, 1966