

MULT
1086

(1) OWNER:

Name Lloyd Corporation
Address 720 NE 12th Ave
Portland, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any—
NE 1/4 NW 1/4 Section 35 T. 1N R. 1E W.M.
Bearing and distance from section or subdivision corner
235 ft. N., 90 ft. E of SW Corner,
Block 112, Holladay's Addition

(4) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(3) PROPOSED USE (check):

Domestic Industrial Municipal
Other Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
16 " Diam. from 0 ft. to 271 ft. Gage 3/8" wall
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Star
SIZE of perforations 3/8" in. by 1 1/4 in.
8 ROWS perforations from 186 ft. to 200 ft.
8 ROWS perforations from 242 ft. to 251 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Model No.
"am. Slot size Set from ft. to ft.
"am. Slot size Set from ft. to ft.

CONSTRUCTION:

Well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 121 ft. below land surface Date Jan. 26, 59
Artesian pressure lbs. per square inch Date

Log Accepted by:

Lloyd Corporation Ltd
[Signed] 3/1, 19 59
7. B. ...
Port. Reg.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Strasser D Co.

Was a pump test made? Yes No If yes, by whom?
Yield: 1100 gal./min. with 7 ft. drawdown after 8 hrs.
" " " " "
" " " " "
" " " " "
Bailer test 150 gal./min. with no ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53 1/2 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 16 inches.

Depth drilled 271 ft. Depth of completed well 271 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Basement	Surface	14
Sandy silt	14	48
Coarse sand and gravel, some clay	48	67
Dirty sand	67	83
Dirty sand and gravel	83	117
Boulders, gravel, and sand	117	134
Loose gravel and sand	134	149
Gravel and sand, some large gravel	149	176
Gravel, some sand and clay	176	182
Loose gravel and sand, water bearing	182	201
Boulders	201	206
Sand, gravel, some clay boulders	206	242
Loose gravel and sand, water bearing	242	254
Cemented gravel	254	271

Work started Dec. 16 19 58 Completed Feb. 11 19 59

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. Strasser Drilling Co.
(Person, firm, or corporation) (Type or print)

Address 8110 SE Sunset Lane, Portland 6, Oregon

Driller's well number 3098

[Signed] Robert J. Strasser partner
(Well Driller)

License No. 10 Date Feb. 20 19 59