

RECEIVED

MAY 25 1961

WATER WELL REPORT

MULT 1087

IE-35K1

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER STATE OF OREGON

G-1691

State Well No.

State Permit No. G-1551

SALEM, OREGON

(1) OWNER:

Name Jantzen, Inc. Address 411 N. E. 19th Ave.

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any-- N.W. 1/4 S.E. 1/4 Section 35 T.I.N. R.I. E. W.M. Bearing and distance from section or subdivision corner North 2307' & East 137' from the S. W. Corner of Timothy Sullivan D.L.C.

TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other [X]

(5) TYPE OF WELL:

Rotary [] Cable [X] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X] 12" Diam. from SURFACE ft. to 182 ft. Gage 43.77

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used Star SIZE of perforations 3/8 in. by 1 1/4 in. 600 perforations from 163 ft. to 173 ft.

SCREENS:

Well screen installed [] Yes [X] No

Manufacturer's Name Model No. Slot size Set from ft. to ft. Slot size Set from ft. to ft.

CONSTRUCTION:

Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [X] Yes [] No To what depth? 52 ft. Material used in seal-- cement grout Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 123 ft. below land surface Date Aug. 1, 1960 Artesian pressure lbs. per square inch Date

Log Accepted by Jantzen Inc. [Signed] Date Aug. 16, 1960 By: Ralph E. Johnston

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Yield: 500 gal./min. with 24 ft. drawdown after 45 hrs. 600 " 33 " 45 " 650 " 39 " 45 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 55° Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well 12 inches.

Depth drilled 182 ft. Depth of completed well 182 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(Sidewalk pipe)

FROM TO

Table with 3 columns: Formation, FROM, TO. Rows include Brown sand and silt, Yellow clay and sand, Yellow clay and gravel, Cemented gravel, Water bearing sand and gravel, Packed sand and gravel.

Work started July 5 19 60 Completed Aug. 8 19 60

(13) PUMP:

Manufacturer's Name Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. STRASSER DRILLING CO. (Person, firm, or corporation) (Type or print)

Address 8110 S. E. Sunset Lane, Portland 6.

Driller's well number 4024

[Signed] Robert J. Strasser (Well Driller)

License No. 10 Date August 15, 1960