

NC

RECEIVED

MULT. 1102

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.
STATE ENGINEER, SALEM OREGON (Please type or print)

State Well No. 1N/1-36 H
State Permit No. _____

(1) OWNER:

Name ALL SAINTS CHURCH
Address 3847 N.E. GILMAN ST. PORTLAND, ORE.

(2) LOCATION OF WELL:

County MULT. Driller's well number 4214
SE 1/4 NE 1/4 Section 36 T. 1N R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): PRODUCTION WELL

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 230 ft. Gage 279
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
280 perforations from 182 ft. to 196 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT
Depth of seal 19 ft. Was a packer used? No
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 162 ft. below land surface Date 11/16/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 400 gal./min. with 15 ft. drawdown after 8 hrs.
" 300 " " 10 " " 1 "
" 200 " " 6 " " 1 "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 230 ft. Depth of completed well 230 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|---------------------------------|------------|------------|
| <u>BROWN CLAY AND SAND</u> | <u>0</u> | <u>69</u> |
| <u>BROWN SAND</u> | <u>70</u> | <u>80</u> |
| <u>BROWN SAND AND CLAY</u> | <u>80</u> | <u>146</u> |
| <u>SAND AND GRAVEL</u> | <u>146</u> | <u>174</u> |
| <u>SAND AND GRAVEL BINDER</u> | <u>174</u> | <u>182</u> |
| <u>LOOSE SAND AND GRAVEL</u> | <u>182</u> | <u>195</u> |
| <u>SAND AND GRAVEL</u> | <u>195</u> | <u>222</u> |
| <u>BROWN CLAY, LARGE GRAVEL</u> | <u>222</u> | <u>230</u> |

Work started OCT 27 1965 Completed DEC 7 1965
Date well drilling machine moved off of well DEC 8 1965

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME RJ STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)
Address 810 SE SUNSET LANE PORTLAND ORE

Drilling Machine Operator's License No. 57

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date DEC. 14, 1965