STATE OF OREGON

WATER WELL REPORT (as required by ORS 537.765)

IW	2	E	-150d

(for official use only)

(1) OWNER:	(10) LOCATION OF WELL by legal description:
Name CITY OF PORTLAND	County MULTDOMAH SE' SW of Section 15 of
Address 12-20 SW STH AVE	Township Range 2E WM.
City PORTLAND State ORE, 971-09	(Township is North or South) (Range is East or West)
(2) TYPE OF WORK (check): No. 29	Tax Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address)
New Well	
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLETED WELL:
Rotary Air Driven Domestic Industrial Municipal	Depth at which water was first found /3/
_ Thermal:	Static level ft. below land surface. Date
Other:	Artesian pressure 2 lbs. per square inch. Date 10/1/8
Bored Piezometric Grounding Test	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Threaded Plastic Welded Welded Threaded Diam. from ft. to Threaded Gauge Threaded LINER INSTALLED: Steel Plastic Plastic Welded	Depth drilled ### ft. Depth of completed well ### ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED: Steel □ Plastic □ Threaded □ Welded □	MATERIAL From To SWL
	SEE ATTACHED SHEET
(6) PERFORATIONS: Perforated? Yes No in. by	
perforations from ft. to ft.	
perforations from ft. to ft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? X Yes \(\text{No} \) No Manufacturer's Name \(\text{No} \) \(\text{JOHNSON} \) Type \(\text{STAINLESS} \) \(\text{STEEL} \) Model No. \(\text{Diam.} \) Diam. \(\text{Slot Size} \) \(\text{Set from} \) ft. to \(\text{ft.} \) On WILLIA TRICKING \(\text{Drawdown is amount water level is lowered} \)	
(8) WELL TESTS: below static level	
Was a pump test made? Yes \(\subseteq \text{No} \) If yes, by whom? \(\subseteq \text{TRASSER} \)	
d: 1900 gal./min. with 193t. drawdown after 14 hrs.	
" " "	
r test gal./min. with drill stem at ft. hrs.	
sailer test gal./min. with ft. drawdown after hrs.	
Artesian flow 75 g.p.m.	
perature of water Depth artesian flow encountered 3.5.6. ft.	Date work started JULY 9 1984 completed OCT 9 1984
'9) CONSTRUCTION: Special standards: Yes \(\text{No} \) \(\text{No} \) \(\text{Vell seal} \) - Material used \(\text{CEMENT} \)	Date well drilling machine moved off of well OCT 10 19849
Well sealed from land surface to 36FF AND 895-315 ft.	(unbonded) Water Well Constructor Certification (if applicable):
Diameter of well bore to bottom of seal in.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	miormation reported above are true to my best knowledge and benef.
Amount of sealing material sacks 2 pounds □	[Signed] Date, 19,
How was cement grout placed? PUMPED IN FROM BOTTOM UP 78 CASING IS REMOVED AND WITH	(bonded) Water Well Constructor Certification: Bond 6373796 Issued by: FIREHANS FUND ISS Co
DUMP BEFORE CASING IS DEIDEN 295-315	(Surety Company Name)
Was pump installed? Type HP Depth ft.	On behalf of KOBERT L. STRASER. (type or print name of Water Well Constructor)
Was a drive shoe used? Yes No Plugs Size: location ft.	(A)
Did any strata contain unusable water? Yes X No	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
Type of Water? depth of strata	Colot the Me
Method of sealing strata off	(Signed) (Water Well Constructor)
Was well gravel packed? Yes No Size of gravel:	(Dated) OCT 23, 1984

Phone: 771-2355

MULT 1139 | DECENTED OCT 24 1984 R. J. Strasser Drilling Co. WATER RESOURCES DEPT. SALEM. OREGON

8110 S. E. Sunset Lane Portland, Oregon 97206

October 22, 1984

Log of well no. 29

top soil	0	_	2
bfown sand and clay	2	_	27
sand and silt	27	_	31
cemented gravel	31	-	131
gravel with clay seams	131	_	158
gravel, silt and sand	158		188
cemented gravel	188	_	236
grey clay	236	_	240
green clay and gravel	240	_	247
clay, silt, and gravel	247	-	268
grey sticky clay	268	_	281
mudstone and sand	281	-	296
brown silty clay	296	_	302
green sticky clay	302	-	321
green sandy clay	321	_	328
grey sticky clay	328	-	347
clay and gravel	347	-	354
black sand	354	-	404
grey sand and gravel	404	_	442
blue clay	442	-	457

Phone: 771-2355

MULT 1139 1 2E - 15 DECE VED

R. J. Strasser Drilling Co.

WATER RESOURCES DEPT. SALEM. OREGON

8110 S.E. Lindy Ave. Portland, Oregon 97206

(7) SCREENS

DIAM 9.5 SLOT SIZE 8 SETTROM 377 FT. TO 387 FT.

DIAM. 9.5 SLOT SIZE 15 SETTROM 387 FT. TO 392 FT.

DIAM. 9.5 SLOT SIZE 26 SETTROM 392 FT. TO 396 FT.

DIAM. 9.5 SLOT SIZE 13 SETTROM 396 FT. TO 402 FT.

DIAM. 9.5 SLOT SIZE 14 SETTROM 402 FT. TO 412 FT.

DIAM 9.5 SLOT SIZE 13 SETTROM 412 FT. TO 416 FT.

DIAM 9.5 SLOT SIZE 13 SETTROM 416 FT. TO 423 FT.

DIAM 9.5 SLOT SIZE 13 SETTROM 416 FT. TO 423 FT.

DIAM 9.5 SLOT SIZE 13 SETTROM 416 FT. TO 423 FT.

DIAM 9.5 SLOT SIZE 14 SETTROM 423 FT. TO 438 FT.