' STATE OF OREGON

WATER WELL REPORT (as required by ORS 537.765)

		•
	MULT	•
	1145	
₹		7

JUL 20 1987

REGEIVEU

In/2E	-16	ab
abard	a-	

(1) OWNER: weil Number:	ATEROPESOCATION OF WELL by legal description:			
Name City of Portland	SALEM County Latitude Latitude Longitude Township Nor S, Range 2E E or W, WM. Section 16 NW 14 NE 14			
Address 1120 S.W. 5th Avenue	Township N or S, Range ZE E or W, WM.			
City Portland State OR Zip 97202	Section 16 NW 1/4 NE 1/4			
(2) TYPE OF WORK:	Tax Lot Lot Block Subdivision			
☐ New Well ☐ Deepen ☐ Recondition 【 Abandon _	Street Address of Well (or nearest address)			
(3) DRILL METHOD				
Rotary Air Rotary Mud Cable	(10) STATIC WATER LEVEL:			
Other	6 ft. below land surface. Date 7/8/87			
(4) PROPOSED USE:	Artesian pressure lb. per square inch. Date			
Domestic Community Industrial Irrigation (11) WATER BEARING ZONES:				
☐ Thermal ☐ Injection	_ ` '			
BORE HOLE CONSTRUCTION:	Depth at which water was first found6			
Al Construction approval Yes No. Depth of Completed Well 9	ft. From To Estimated Flow Rate SWL			
Yes No LA Amount Amount				
HOLE SEAL Amount Diameter From To Material From To sacks or pound	ls			
0 334 *cement 8 338 125 sacks	<u> </u>			
7? 334 338 soil 0 8 as req'd	(12) WELL LOG: Ground elevation Approx. 25			
	Material From To SWL			
*placed inside casing after perforating	— No new drilling. Well was reportedly			
How was seal placed: Method A B C D E	drilled by Haakon Bottner for W.L. Menke			
🗓 Other pressure grouted with submerged pipe	— in 1959 to a depth of 345'.			
Backfill placed fromft. toft. Material				
Gravel placed fromft. toft. Size of gravel				
(6) CASING/EINER: REMOVED				
Diameter From To Gauge Steel Plastic Welded Thread	ed			
Liner:				
Final location of shoe(s)	_			
PERFORATIONS/SCREENS:				
X Perforations Method Rotary				
☐ Screens Type Material				
Slot Tele/pipe				
m To size Number Diameter size Casing Liner				
334 .1x1 6700 X				
	Date started 7/9/87 Completed 7/16/87			
(0) WWY I BY GROUP	(unbonded) Water Well Constructor Certification:			
(8) WELL TESTS: Minimum testing time is 1 hour Flowing	I certify that the work I performed on the construction, alteration, or			
☐ Pump ☐ Bailer ☐ Air ☐ Artesian	abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my besi			
Yield gal/min Drawdown Drill stem at Time	knowledge and belief.			
1 hr.	WWC Number 1394			
Not applicable	Signed uzene Mack Date 7/17/87			
	(bonded) Water Well Constructor Certification:			
Temperature of water Depth Artesian Flow Found	I accept responsibility for the construction, alteration, or abandonmen			
work performed on this well during the construction dates reported above				
Did any strata contain water not suitable for intended use? Too little	 work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and 			
☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other	belief. WWC Number 649			
Depth of strata:	Signed Liphun suknuku Date 7/17/87			
	Date			