

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED
MAR 2 1970

STATE OF OREGON
(Please type or print)

(Do not write above this line)

STATE ENGINEER
SALEM, OREGON

MULT
1161

State Well No. IN/2-236a

State Permit No. _____

(1) OWNER:

Name PARKROSE WATER DISTRICT
Address 10424 NE TREMONT PORTLAND ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
24" Diam. from +4 ft. to 41 ft. Gage 375
22" Diam. from 39 ft. to 41 ft. Gage 375
22" Diam. from 61 ft. to 65 ft. Gage 375

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name U.O.P. JOHNSON
Type STAINLESS STEEL Model No. _____
Diam. 24 Slot size 10 Set from 41 ft. to 61 ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 17 ft. below land surface Date 2/18/70
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STRASSER

Yield: 2000 gal./min. with 17 ft. drawdown after 22 hrs.
2250 " 20 " 23 "
2325 " 24.5 " 26 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 52° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CONCRETE

Depth of seal 0 - 20 ft.

Diameter of well bore to bottom of seal 36 in.

Were any loose strata cemented off? Yes No Depth _____

Was a drive shoe used? Yes No

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County MULT. Driller's well number 5235
NE 1/4 NW 1/4 Section 23 T. 1N R. 2E W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 65 ft. Depth of completed well 65 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	4	
BOULDERS AND GRAVEL	4	20	
GRAVEL BOULDERS AND CLAY	20	27	
LOOSE SAND GRAVEL AND BOULDERS	27	60	
CEMENTED GRAVEL	60	65	

Work started DEC 27 1969 Completed FEB 24 1970

Date well drilling machine moved off of well FEB 24 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Don Johnson Date FEB 26 70
(Drilling Machine Operator)

Drilling Machine Operator's License No. 56

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LAKE PORTLAND ORE.

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date FEB 24, 1970.