

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

MAR - 8 1965 STATE OF OREGON
(Please type or print)

MULT
1164

State Well No. 1N/2 - 23 C
State Permit No. _____

(1) OWNER: SALEM OREGON
Name PARKROSE WATER DISTRICT
Address 10424 NE FREEMONT ST. PORTLAND ORE.

(2) LOCATION OF WELL:
County MULT Driller's well number 4119A
NE 1/4 NW 1/4 Section 23 T. 1N R. 2E W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check): CAPPED AND NOT COMPLETED
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
24" Diam. from 0 ft. to 63 ft. Gage 375
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used CUTTING TORCH
Size of perforations 3/8 in. by 4 in.
540 perforations from 33 ft. to 63 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
_____ Slot size _____ Set from _____ ft. to _____ ft.
_____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION: Well seal—Material used in seal CEMENT GROUT
Depth of seal 20 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 30 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 24 ft. below land surface Date 1/22/62
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level RJ STRASSER DRILLING Co.
Was a pump test made? Yes No If yes, by whom? _____
Yield: 1800 gal./min. with 8 ft. drawdown after 8 hrs.
" 2450 " 13 " 16 "
" " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 63 ft. Depth of completed well 63 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SILT CLAY AND SAND	0	7
BOULDERS	7	21
GRAVEL COBBLES AND CLAY	21	43
COBBLE STONE	43	48
COARSE GRAVEL	48	56
CEMENTED GRAVEL	56	63

Work started DEC 23 1961. Completed JAN 26 1962
Date well drilling machine moved off of well JAN 26 1962

(13) PUMP: Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME RJ STRASSER DRILLING Co
(Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORT ORE
Drilling Machine Operator's License No. 57
[Signed] Robert L. Strasser
(Water Well Contractor)
Contractor's License No. 10 Date FEB 22 1965