

Mult. Co 1N/2E-24ac
20-City of Portland

RECEIVED

JUN 30 1982

WATER RESOURCES DEPT
SALEM, OREGON

CITY OF PORTLAND WELL No.

(5) LINER INSTALLED

8 INCH STAINLESS STEEL PIPE .180 WALL THICKNESS FROM 376.5 TO 413.5 FT. WITH A 1 INCH THICK RUBBER PACKER 12 IN. LONG AT 377 AND A 1 INCH THICK RUBBER PACKER 18 INCHES LONG AT 411 FT.

8 INCH P.V.C. PIPE .322 WALL THICKNESS FROM 413.5 TO 453.5 FEET WITH 1 INCH THICK RUBBER PACKERS 18 INCHES LONG AT 415.5, 431, AND 451 FEET.