## WATER WELL REPORT STATE OF OREGON



## RECEIVEDIN 28-24 ba FEB 23 1982 State Permit No.

WAT

TER RESOURCES DENT 1	_
SALE OREGON HULLIAN	_

(1) OWNER:	(10) LOCATION OF WELL:	
Name CITY OF PORTLAND	County MULT, Driller's well number 5586	
Address 1220 SW 5TH AUE	NE 4 NW 4 Section 24 T. IN R. 2E W.M.	
City FORTLAND State ORE 97209	Tax Lot # Lot Blk Subdivision	
(2) TYPE OF WORK (check): WELL No 10	Address at well location:	
New Well Deepening □ Reconditioning □ Abandon □  If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
	Depth at which water was first found ft.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level ft. below land surface. Date	
Rotary Air Driven Domestic Industrial Municipal Setary Mud Dug Dirrigation Test Well Dotter	Artesian pressure 1.5 lbs. per square inch. Date //12/82	
Bored	(12) WELL LOG: Diameter of well below casing	
(5) CASING INSTALLED: Steel Y Plastic	Depth drilled 375 ft. Depth of completed well 375 ft.	
Threaded Welded Welded William from 12.5 ft. to 27.5 ft. Gauge 37.5 ft. to 27.5 ft. Gauge 37.5	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.	
LINER INSTALLED: 375	MATERIAL From To SWL	
"Diam. from	SEE ATTACHED SHEET	
6) PERFORATIONS: Perforated?   Yes You		
Type of perforator used		
Size of perforations in. by in.		
perforations fromft. toft.		
perforations from ft. to ft.		
perforations from ft. to ft.		
(7) SCREENS: Well screen installed? XYes \( \square\) No Manufacturer's Name \( \square\) D JOHNSON		
Type STAINIESS STEEL Model No.		
Diam. 3 E ASTONS ACHE TOM SHEET to ft.		
Diam. Slot Size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
s a pump test made? Yes \( \subseteq \text{No If yes, by whom?} \)		
Meld: 2500 gal./min. with /96ft. drawdown after 48 hrs.		
" " "		
ir test gal./min. with drill stem at ft. hrs.		
Bailer test gal./min. with ft. drawdown after hrs.		
sian flow 75 g.p.m.		
Depth artesian flow encountered ft.	Work started SEPT 14 19 81 Completed JAN 20 19 62	
) CONSTRUCTION: Special standards: Yes $\square$ No	Date well drilling machine moved off of well FEB 9 1982	
Well seal—Material used CEMENT CTROUT	Drilling Machine Operator's Certification:	
Well sealed from land surface to 47 fr. 740 265 - 275ft.	This well was constructed under my direct supervision. Materials used	
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and helief.	
Diameter of well bore below seal	[Signed] J. Date	
Number of sacks of cement used in well seal sacks  How was cement grout placed? PUMPED THEO SH	Drilling Machine Operator's License No.	
ONE INCH PLASTIC PIPE FROM	Water Well Contractor's Certification:	
BOTTOM AS CASING WAS REMOVED	This well was drilled under my jurisdiction and this report is true to	
Was pump installed? Ng Type HP Depth ft.	the best of my knowledge and belief.	
Was a drive shoe used?   ✓ Yes □ No Plugs Size: location ft.	Name KISTRASSER DELLING CO	
Did any strata contain unusable water?   Yes No	Address 8110 SE SUNSET LANG FRETLANDORS	
Type of Water? depth of strata	[Signed] Robert I thanks	
Method of sealing strata off	[Signed] (Water Well Contractor)	
Was well gravel packed? ☐ Yes No Size of gravel:	Contractor's License No. Date #EB 32, 1982	
Gravel placed from		

Phone: 771-2355

RECEIVED

FEB 23 1982

WATER RESOURCES DEPT SALE ... OREGON

## R. J. Strasser Drilling Co.

8110 S. E. Sunset Lane Portland, Oregon 97206

February 19, 1982

20-Ctyd Pottand IN/2E-34ba Mutt. Co.

Log of production well #10

top soil	0 - 1
gravel	1 - 2
grey clay	2 - 17
cemented gravel and boulders	17 - 33
cemented gravel, grey clay	33 - 93
grey clay and gravel	93 - 97
sand, gravel and brown clay	97 - 105
cemented gravel, grey clay	105 - 144
green clay, some gravel	144 - 163
green and grey clay	163 - 170
sandy grey clay	170 - 180
grey clay	180 - 188
sandy grey clay	188 - 203
grey and green clay	203 - 210
sandy green clay	210 - 237
sticky grey clay	237 - 250
green clay, gravel and sand	250 - 252
dark green sandy clay	252 - 266
green and grey clay	<b>266 - 278</b>
green clay, sand and gravel	278 - 290
sandstone, clay seams	290 - 300
slightly cemented sand and gravel	300 - 347
cemented sand and gravel	347 - 350
slightly cemented sand and gravel	350 - 375

## RECEIVED

FEB 23 1982.

WATER RESTURCES DEPT SALEM, OREGON

(7) SCREENS

DIAM, 12 IN SLOT SIZE 25 FROM 282 TO 310 FF.

DIAM, 12 IN SLOT SIZE 20 FROM 310 TO 316 FF.

DIAM, 12 IN SLOT SIZE 11 FROM 316 TO 332 FF.

DIAM, 12 IN SLOT SIZE 16 FROM 382 TO 345 FF.

DIAM, 12 IN SLOT SIZE 12 FROM 345 TO 358 FF.

DIAM, 12 IN SLOT SIZE 10 FROM 358 TO 365 FF.

20-City of Portland Well#16 Mult: IN/2E-24ba