

RECEIVED JUN 1 1961

MULT 1212

IN/2E-26M2

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER WATER WELL REPORT SALEM, OREGON STATE OF OREGON

State Well No. 61562 State Permit No.

(1) OWNER: (Wm. Stoker) Columbia Sand & Gravel Name Address 2234 N.E. 122 Av. Portland Oregon

(2) LOCATION OF WELL: County Mult. Owner's number, if any - 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): Well [x] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check): Domestic [] Industrial [x] Municipal [] Irrigation [] Test Well [] Other []

(6) CASING INSTALLED: Threaded [] Welded [x] 8" Diam. from 0 ft. to 313 ft. Gage 330 6" Diam. from 305 ft. to 377 ft. Gage

(7) PERFORATIONS: Perforated? [x] Yes [] No Type of perforator used Star drive down SIZE of perforations 3/8 in. by 1-1/4 in. 200 perforations from 305 ft. to 315 ft. 100 perforations from 365 ft. to 370 ft.

(8) SCREENS: Well screen installed [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [x] Yes [] No To what depth? 27 ft. Material used in seal - sand & cement Did any strata contain unusable water? [] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 203 ft. below land surface Date 4/15/61 Artesian pressure lbs. per square inch Date

Log Accepted by: [Signed] (Owner) Date 1961

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Bottner Yield: 140 gal./min. with 23 ft. drawdown after 24 hrs.

(12) WELL LOG: Diameter of well 8 inches. Depth drilled 388 ft. Depth of completed well 377 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Gravel & boulders, Clay & gravel, Sand & gravel, Gravel & Boulders, Cemented Gravel, Yellow Sand, Sand & Gravel (water), Clay & Gravel, Gravel (water), Blue Clay.

Work started 19 Completed 19

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Bottner Drilling Co. (Type or print) Address 11544 N.E. Glisen Portland Ore. Driller's well number [Signed] H. Bottner (Well Driller) License No. 109 Date May 19, 1961

made from 6-1-61