

ORIGINAL
File Original and
Duplicate with the
STATE ENGINEER,
SALEM, OREGON

RECEIVED
SEP 16 1958

WATER WELL REPORT

State Well No. 11/2-26 M(1)
State Permit No. 6812

STATE ENGINEER MULT
STATE OF OREGON

(1) OWNER: SALEM, OREGON
Name PARKROSE SCHOOL DISTRICT #3, Mult. County
Address 10613 N. E. Prescott
Portland 20, Oregon

(2) LOCATION OF WELL: 12456 N. E. Brazee
County Multnomah Owner's number, if any—
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

TYPE OF WORK (check):
All Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):
 Industrial Municipal
 Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
10" Diam. from 0 ft. to 399810 ft. Gage STANDARD
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used STAR 1/4 Way Drive Down
SIZE of perforations 3/8 in. by 1 1/4 in.
96 perforations from 222 ft. to 226 ft.
268 perforations from 374 ft. to 386 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

SCREENS: Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

INSTRUCTION:
Gravel packed? Yes No Size of gravel: _____
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 30 ft.
Material used in seal— Sand Gravel & Cement
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 236 ft. below land surface Date 7/23/58
Artesian pressure lbs. per square inch Date

Log Accepted by: Parkrose Public Schools
[Signed] _____ Date _____, 19____
by _____ Owner _____ Supt

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? WELL DRILLING
Yield: 150 gal./min. with 4 1/2 ft. drawdown after 3/8 hrs.
" 200 " " 6 " " 1 " "
" 250 " " 7 1/2 " " 1 1/8 " "
Bailer test 350 gal./min. with 8 1/2 ft. drawdown after 4 hrs.
Artesian flow 450 " " 9 1/2 " " 5 " "
Temperature of water 49° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 10 inches
Depth drilled 415 ft. Depth of completed well back filled to 410 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Gravel & Boulders	3	10
Boulders	10	16
Br. Clay, Sand & Gravel	16	26
Boulders	26	32
Gray Clay, Sand & Gravel	32	42
Real Large Boulders	42	46
Cemented Gravel	46	54
Boulders	54	58
Cemented Gravel	58	74
Loose Pea Gravel	74	81
Cemented Gravel & Boulders	81	94
Loose Gravel & Boulders	94	120
Cemented Gravel	120	130
Loose & Cemented Gravel	130	145
Very Loose Gravel & Sand	145	209
Cemented Gravel	209	223
Gravel (w. Bearing) approx. 100gpm	223	225
Cemented Gravel	225	245
Sandy Yellow Clay	245	265
Bluish Sandy Clay	265	275
Cemented Gravel	275	299
Yellow Sand	299	300
Cemented Gravel (water br.)	300	371
Large & Small Grv. some sand)	371	386
Real Tight C. Gravel	386	412
GRAY & BLUE CLAY Completed	412	412

(13) PUMP: Completed July 23/58
Manufacturer's Name _____ H.P. _____
Type: _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME HAakon I. BOTTNER WELL DRILLING
(Person, firm, or corporation) (Type or print)
Address 11544 N. E. GLISAN ST.
Driller's well number _____
[Signed] _____ (Well Driller)
License No. 109 Date AUG. 12, 1958