WATER WELL REPORT STATE OF OREGON



RECEIVED 14 /3E - 196d MAR 3 1 1982

WATER RES TREES TO BET SALL... OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name OF FORTLAND	County MULT, Driller's well number 338
Address 1220 SW 5TE AVE	SE4 NN 4 Section 19 T. IN R. 3E W.M.
City PORTLAND State ORE 9720	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check): WELL No. 9	Address at well location:
New Well	(11) WATER LEVEL Completed and
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.
Rotary Air Driven Domestic Industrial Municipal	Static level ft. below land surface. Date Artesian pressure lbs. per square inch. Date 3 12 82
Rotary Mud	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled 495 ft. Depth of completed well 490 ft.
(5) CASING INSTALLED: Steel Plastic Welded Welded	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED: 17/ 1365	MATERIAL From To SWL
10"Diam. from	SEE ATTACHED SHEET
	JEE HIMCHEL SAPEL
(6) PERFORATIONS: Perforated? ☐ Yes No Type of perforator used	
Size of perforations in. by in.	
perforations from ft. to ft.	
perforations fromft. toft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? Yes \(\subseteq \text{No} \)	
Manufacturer's Name LOP Johnson	
Type DTAINLESS STEELModel No. 196	
Diam	
Diam. Slot Size Set from ft. to ft. to	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Wes a pump test made? XYes \(\subseteq No \) If yes, by whom? STLASSER	
d: 2500 gal./min. with 7/ ft. drawdown after 24 hrs.	
" " " "	
Air test gal./min. with drill stem at ft. hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Mesian flow 200 g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started Nov /3 198/ Completed MAR 221982
(9) CONSTRUCTION: Special standards: Yes \(\text{No } \text{ No }	Date well drilling machine moved off of well MAR 17 19 82
Well seal—Material used CEMENT GROUT	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and helief.
Diameter of well bore below seal	[Signed] Date
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No
How was cement grout placed? PUMPED THRU CTROUT PIPE FROM BUTTOM UP AS THE	Water Well Contractor's Contification
CASING WAS FULLED	Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to
Was pump installed? Type HP Depth ft.	the best of my knowledge and belief.
Was a drive shoe used? Yes \(\subseteq \text{No} \) Plugs Size: location ft.	Name KJ STRASSER JR/LUNCT CO
Did any strata contain unusable water? Yes No	Address 8105E SWSET LANE PORTLANDORE
Type of Water? depth of strata	Q Do Actor
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? Yes No Size of gravel 2-20 SAN	Contractor's License No. 10 Date MAR 25 1982
Gravel placed from34.8 ft. to4.9.0 ft.	

Phone: 771-2355

RECEIVED

MAR 3 1 1982

R. J. Strasser Drilling Co.

WATER RESOURCES DEPT SALE.... OREGON

8110 S. E. Sunset Lane Portland, Oregon 97206 March 29, 1982

No. 9. production well.

brown silty sand	0 - 15
sand, gravel and boulders	15 - 43
sand, gravel and clay	43 - 55
cemented gravel	55 - 79
sand, gravel and silt	79 - 83
slightly loose sand and gravel	83 - 86
sand, cobbles and clay	86 - 89
cemented gravel	89 - 103
sand, gravel and clay	103 - 121
green clay, some gravel	121 - 137
grey clay	137 - 155
sticky green clay	155 - 158
grey clay	158 - 167
grey and green clay	167 - 174
sticky green clay	174 - 190
green, brown and grey clay	190 = 215
dark grey sandstone	215 - 256
dark grey sticky clay	256 - 258
cemented gravel	258 - 303
sticky grey clay	303 - 313
cemented gravel	313 - 317
sticky grey, green and tan clay	317 - 371
cemented gravel	371 - 395
green clay, some gravel	395 - 398
cemented gravel	398 - 413
sand, silt and gravel	413 - 447
boulders and gravel	447 - 449
cemented sand and gravel	449 - 469
sand and gravel	469 - 484
sand and silt	484 - 486
black sand, some silt	486 - 490
sandy clay	490 - 495
warming wand	

IN/3E-196d

R. J. Strasser Drilling Co.

8110 S. E. Sunset Lane Portland, Oregon 97206

April 27, 1982

RECUED

APR 29 1982

WATER RESOURCES DEPT

BALEM. OREGON

City of Portland
addendum to production well #9

(9) Construction well sealed with cement grout from 105 to 125 feet well sealed with cement grout from 350 to 370 feet