

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT

**RECEIVED**

OCT 26 1978

STATE OF OREGON  
(Please type or print)

Do not write above this line

MULT  
001295

State Well No. 1N/3E-2/d6

State Permit No. \_\_\_\_\_

WATER RESOURCES DEPT.

(1) OWNER: SALEM, OREGON

Name Richard A. DelPizzo  
Address 10400 S. E. 98th Ct., Portland, Or. 97266

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

CASING INSTALLED: Threaded  Welded   
8" Diam. from 7.2 ft. to 130 ft. Gage 0.250  
6" Diam. from 120 ft. to 173 ft. Gage 0.250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS: Perforated?  Yes  No.

Type of perforator used Torch  
Size of perforations 12 in. by 1/4 in.  
88 perforations from 130 ft. to 168 ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_ Model No. \* \_\_\_\_\_  
Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made?  Yes  No If yes, by whom? Steinman Bros. Dr. Co.  
Yield: 200 gal./min. with 33 ft. drawdown after 24 hrs.  
" " " " " "  
" " " " " "  
Baller test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water 54 Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to 26 ft.  
Diameter of well bore to bottom of seal 12 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 55 sacks  
How was cement grout placed? Pumped through a one inch pipe between 12 inch and 8 inch casing  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: 3/8" minus  
Gravel placed from 26 ft. to 170 ft.

(10) LOCATION OF WELL:

County Multnomah Driller's well number 52-78  
NW 1/4 SE 1/4 Section 21 T. 1N R. 3E W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 135 ft.  
Static level 45 ft. below land surface. Date 10/11/78  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing \_\_\_\_\_

Depth drilled 173 ft. Depth of completed well 170 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Silt, brown	0	8	
Silt, grey with lenses	8	18	
Siltstone, dark grey	18	36	
Conglomerate	36	93	
Grey Silt	93	97	
Conglomerate	97	104	
Clay, grey	104	135	
Sandstone, green & grey	135	164	45
Conglomerate	164	---	

Work started Sept. 25 19 78 Completed Oct. 19 19 78  
Date well drilling machine moved off of well Oct. 20 19 78

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Steven Steinman Date Oct. 20, 19 78  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 54

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Steinman Bros. Drilling Co.  
(Person, firm or corporation) (Type or print)  
Address 14912 S.E. Kellogg Ave., Milwaukie, Or. 97222  
[Signed] Robert E. McConnell  
(Water Well Contractor)  
Contractor's License No. I Date Oct. 20, 19 78